



BRANZ Appraised
Appraisal No. 1005 [2018]

ALUPLAST® UPVC WINDOWS AND DOORS

Appraisal No. 1005 [2018]
Amended 19 November 2018



BRANZ Appraisals

Technical Assessments of
products for building and
construction.



aluplast® GmbH

Auf der Breit 2
D-76227
Karlsruhe
Germany

Email: sales.international@
aluplast.net

Web: www.aluplast.net



BRANZ

BRANZ

1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908
Porirua 5240,
New Zealand
Tel: 04 237 1170
branz.co.nz



Product

- 1.1 aluplast® uPVC Windows and Doors are a range of double and triple-glazed window and door joinery units for use in residential and light commercial buildings. The joinery units are available with fixed glazing or opening sashes. The opening sash window styles include Awning, Bi-fold, Casement, Sliding, and Tilt and turn. Door styles include Inward and Outward Opening Hinged, Bifold and French Doors, Sliding and Tilt-and-slide Doors.
- 1.2 The aluplast® uPVC Windows and Doors covered by this Appraisal are referred to as IDEAL 2000 and Multi Slide.
- 1.3 The windows and doors are fabricated in New Zealand by NK Window Solutions Ltd and Cascade International Ltd trading as Warm Windows, from uPVC profiles manufactured by aluplast® GmbH in Germany.

Scope

- 2.1 aluplast® uPVC Windows and Doors have been appraised for use as window and door joinery within the following scope:
 - designed and manufactured in accordance with NZS 4211 for weathertightness, airtightness and structural design; and,
 - as an alternative to the aluminium windows and doors specified in NZBC Acceptable Solution E2/AS1 Paragraph 9.1.10; and,
 - in buildings within the scope limitations of NZBC Acceptable Solution E2/AS1, Paragraph 1.1, and,
 - with cladding systems complying with NZBC Acceptable Solution E2/AS1, and,
 - situated in NZS 3604 defined Wind Zones up to and including High for Multi Slide doors and up to and including Extra High for all other window and door types.
- 2.2 aluplast® uPVC Windows and Doors have also been appraised for compliance with NZS 4211 where they are specified for use outside the scope of NZBC Acceptable Solution E2/AS1, Paragraph 9.1.10.1 [as the product is uPVC, not aluminium] and/or the building is outside the scope limitations of NZBC Acceptable Solution E2/AS1 Paragraph 1.1 but is within the wind exposure limitations of NZS 4211. The building weather-tightness design and installation of the window and door joinery in these situations is subject to specific design and is outside the scope of this Appraisal.
- 2.3 aluplast® uPVC Windows and Doors in sizes above those tested have also been appraised for compliance with NZS 4211 where the proprietary aluplast® window system engineering design system, or a design engineer, is able to verify that the strength and deflection requirements are within the limitations of the applicable wind zone.

Building Regulations

New Zealand Building Code (NZBC)

3.1 In the opinion of BRANZ, aluplast® uPVC Windows and Doors, if used, designed, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet, or contribute to meeting the following provisions of the NZBC:

Clause B1 STRUCTURE: Performance B1.3.1, B1.3.2 and B1.3.4. aluplast® uPVC Windows and Doors meet the requirements arising for loads from self-weight, wind and impact, i.e. B1.3.3(a), (h) and (j). See Paragraphs 9.1 to 9.3.

Clause B2 DURABILITY: Performance B2.3.1(b), 15 years for the windows and doors and B2.3.1(c), 5 years for the hardware. aluplast® uPVC Windows and Doors meet these requirements. See Paragraphs 10.1 to 10.5.

Clause E2 EXTERNAL MOISTURE: Performance E2.3.2. aluplast® uPVC Windows and Doors meet this requirement for the joinery unit and contribute to the wall cladding system meeting this requirement. See Paragraphs 14.1 to 14.4.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.2 and F2.3.3(a). aluplast® uPVC Windows and Doors meet these requirements. See Paragraph 15.1.

Clause F4 SAFETY FROM FALLING: F4.3.1. aluplast® uPVC Windows and Doors meet this requirement. See Paragraph 16.1.

Clause G4 VENTILATION: Performance G4.3.1 and G4.3.3. aluplast® uPVC Windows and Doors can be used to meet these requirements. See Paragraph 18.1.

Clause G7 NATURAL LIGHT: Performance G7.3.1 and G7.3.2. aluplast® uPVC Windows and Doors can be used to meet these requirements. See Paragraph 19.1.

Clause H1 ENERGY EFFICIENCY: Performance H1.3.1 and H1.3.2E. aluplast® uPVC Windows and Doors contribute to meeting these requirements. See Paragraph 20.1

Technical Specification

4.1 aluplast® IDEAL 2000 uPVC Windows and Doors are fabricated in a variety of extruded uPVC profiles. The uPVC is a tropical formulation for use in countries with high UV levels such as New Zealand. IDEAL 2000 is based on a 60 mm frame depth. All profiles incorporate internal steel core profiles for additional rigidity. The finished profiles are of various cross-sectional designs, both in sizing and format to allow for differing strengths, glazing and sash types.

4.2 aluplast® uPVC is offered in a standard white colour. aluplast® also offer alternative colour options which are achieved by application of a coloured PVDF acrylic foil. The foil is laminated onto the surface of the profiles when it is extruded. Colour stability testing has been assessed by BRANZ for the following colours: Golden Oak [F436-2035], Alux DB [F436-1014A] and Black Brown [F436-5010]. Other colours are available but these have not been assessed and are outside the scope of this Appraisal.

4.3 Seals and gaskets used in the aluplast® uPVC Window and Doors are co-extruded EPDM.

4.4 Each joinery unit is assembled from uPVC profiles selected according to the window or door sizing. Window and door accessories include fasteners, safety stays, friction stays, sash locks, and door hardware.

4.5 Each joinery unit bears the brand name, a rating showing the appropriate NZS 4211/ NZS 3604 wind zone, and an indication of air leakage level.

4.6 H3.1 treated timber reveals are attached to the frames.

4.7 For double and triple-glazing, the glazing must be selected in accordance with the requirements of NZS 4223 Part 3 and AS/NZS 4666.



Accessories

- 4.8 Accessories used with aluplast® uPVC Windows and Doors which are supplied by the window fabricator are:
- Joinery sill support bars and fixings complying with NZBC Acceptable Solution E2/AS1 Paragraph 9.1.10.5 b) v).
 - Head flashings complying with NZBC Acceptable Solution E2/AS1 Paragraph 9.1.10.4.
 - Sill flashings [for direct fixed claddings] complying with NZBC Acceptable Solution E2/AS1 Paragraph 9.1.10.5.
- 4.9 Fixings used to fit aluplast® uPVC Windows and Doors to the framing which are supplied by the window installer are minimum:
- 65 mm x 8g stainless-steel screws, or
 - 75 x 3.15 mm hot-dip galvanised nails.

Handling and Storage

- 5.1 Handling and storage of aluplast® uPVC Windows and Doors onsite is the responsibility of the window installer. Joinery units must be handled with care to avoid damage, especially scratching, and must be stored under cover on edge, and supported on the sill with protection materials (e.g. timber blocking) to avoid damage and distortion.
- 5.2 Bituminous products must be kept off the surface of uPVC to avoid staining. Solvent based products must not be allowed to come into contact with the surface of the uPVC.

Technical Literature

- 6.1 Refer to the Appraisals listings on the BRANZ website for details of the current Technical Literature for aluplast® uPVC Windows and Doors. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

- 7.1 Design of the aluplast® uPVC joinery units is carried out to meet the requirements of NZS 4211 and NZS 4223 Part 3 by local aluplast® Agents.
- 7.2 It is recommended that an aluplast® Agent is consulted for information and recommendations on window size, configuration and glass requirements.
- 7.3 Where combinations of fixed lights and opening sashes are required, the height of the window will depend on the maximum allowable mullion height for the wind exposure and the mullion spacing selected. The joinery can be of any width, provided the width of any light is within the maximum allowable transom length and the maximum allowable sash width. In all cases, the glass installed must meet the structural requirements for the wind exposure selected.
- 7.4 Where aluplast® uPVC Windows and Doors are used with proprietary cladding systems not covered by NZBC Acceptable Solution E2/AS1, designers must detail the junction between aluplast® uPVC Windows and Doors and the cladding to meet their own requirements and the performance requirements of the NZBC. Details not included within the Technical Literature have not been assessed and are outside the scope of this Appraisal.

Joinery Security

- 8.1 The joinery units incorporate multi-point locks and as such that when closed, sashes cannot be readily opened from the outside by, for example, the insertion of a thin blade.

Structure

- 9.1 The structural performance of aluplast® uPVC Windows and Doors meets the requirements of NZS 4211.

Wind Zones

- 9.2 The joinery is suitable for use in all Wind Zones of NZS 3604, up to and including Extra High, with the exception of multi slide doors which are suitable for use in all wind zones of NZS3604, up to and including High

Ease of Operation

- 9.3 The sashes meet the opening force requirements of NZS 4211, Paragraph 7 and can be opened without difficulty.

Durability

Serviceable Life

- 10.1 aluplast® white tropical uPVC joinery profiles and associated EPDM gaskets and seals are expected to remain serviceable under New Zealand conditions of use for a period of at least 15 years, if installed and maintained in accordance within the specifications of aluplast® GmbH. Over time, some loss of gloss, and some colour fade may affect the surface appearance of the uPVC profile.
- 10.2 Coloured PVDF acrylic foils laminated onto the uPVC profiles can also be expected to remain serviceable for at least 15 years. Over time, some loss of gloss and some colour fade may affect the surface appearance of the foil.
- 10.3 During the life of the joinery, components such as hardware fittings and seals may need to be replaced due to environmental exposure and damage.
- 10.4 Glazing installed in aluplast® uPVC Windows and Doors is subject to the performance requirements of NZS 4223. Double glazing must in addition meet the requirements of AS/NZS 4666. Glazing installed to the above requirements is expected to have a serviceable life of at least 15 years.
- 10.5 H3.1 timber reveals meet the 15 year durability performance requirements of NZS 3602.

Maintenance

- 11.1 aluplast® uPVC Windows and Doors must be regularly cleaned (at least annually) using warm water containing a mild household detergent to remove any grime, dirt and organic growth that may have accumulated and to maximise the life and appearance of the joinery. If proprietary cleaners are used on the glass, care must be taken to ensure that deposits do not discolour or damage the uPVC surface or window seals. Organic solvents, particularly acetone and toluene based solvents, and similar products must not be used for cleaning as they could damage the surface of the uPVC profiles. aluplast® Agents should be consulted first to ascertain suitability before any solvent based product is used for cleaning.
- 11.2 Hardware should be periodically lubricated to minimise wear and to ensure smooth operation. Hardware can be readily replaced by aluplast® agents if necessary.
- 11.3 Drainage channels should be cleaned periodically and kept clear of any blockages.
- 11.4 Care must be taken to avoid damage or discolouration of the uPVC profiles when stripping paint from adjacent timber, for example, by means of a blowtorch or paint stripper.
- 11.5 uPVC should not need painting at any time. Should painting be contemplated for any reason, only a specialised paint system may be used. The advice of aluplast® Agents must be sought before any painting is undertaken.
- 11.6 Re-glazing if required, must be undertaken by a glazier following aluplast® agent's installation instructions.

Means of Escape

- 12.1 Where aluplast® uPVC Doors are used on escape routes, the relevant provisions of NZBC Clause C4 must be met. This may be achieved, for example, by meeting the relevant requirements of NZBC Acceptable Solutions C/AS1 – C/AS7 Part 3 for access, door fastenings, locking devices, direction of opening, degree and width of opening, hardware, and provision of vision panels.

Control of Internal Fire and Smoke Spread

- 13.1 aluplast® uPVC Windows and Doors are not suitable for use as fire rated windows or where fire doors or smoke control doors are required by the NZBC.
- 13.2 Risk Group SH buildings have no surface finish requirements [Group Number]. Window components and individual doorsets in other Risk Groups are also exempt from the surface finish requirements. Refer to NZBC Acceptable Solutions C/AS2 – C/AS6 Paragraph 4.17.6 d) and 4.17.6 g).

External Moisture

General

- 14.1 aluplast® Windows and Doors, when installed in accordance with the Technical Literature and installation detailing, perform similarly to and are an Alternative Solution to the windows and doors specified in NZBC Acceptable Solution E2/AS1. aluplast® uPVC Windows and Doors, when correctly installed, prevent the penetration of moisture that could cause undue dampness or damage to building elements.
- 14.2 Buildings outside the scope of NZBC Acceptable Solution E2/AS1 must be the subject of specific weather-tightness design for the joinery installation details. The designer must develop these joinery installation details to meet their own requirements and the performance requirements of the NZBC. These details have not been assessed and are outside the scope of this Appraisal.
- 14.3 All window and door joinery must be installed using flexible flashing tapes and air-seals in accordance with NZBC Acceptable Solution E2/AS1, Paragraphs 9.1.5 and 9.1.6, or when used outside the scope of NZBC Acceptable Solution E2/AS1, specific weather-tightness design details must also follow these principles.

Air and Water Leakage

- 14.4 aluplast® uPVC Windows and Doors comply with the air and water leakage requirements of NZS 4211, Sections 8 and 9. Air leakage rates for the joinery can reach the NZS 4211 air-conditioning rating. Water leakage ratings allow for their installation in NZS 3604 defined Wind Zones up to and including Extra High.

Hazardous Building Materials

Human Impact Safety

- 15.1 Glazing likely to be subject to human impact must comply with NZS 4223: Part 3 as specified in NZBC Acceptable Solution F2/AS1, Paragraph 1.0.

Safety from Falling

- 16.1 Opening windows must comply with the requirements of NZBC Acceptable Solution F4/AS1, Paragraph 2.0. In cases where the fitting of a window opening restrictor is an appropriate solution, these can be fitted on request by an aluplast® Agent during manufacture, or universal restrictor stays can be retrofitted to the joinery units by others.

Restricting Access to Residential Pools

17.1 Openable windows and doors that provide access to the immediate pool area must be carefully considered in the building design stage by the designer, paying particular attention to any requirements for restrictor stays or self-closing and self-latching door hardware. The design of windows and doors and their hardware specifications in these instances are outside the scope of this Appraisal. NZBC Acceptable Solution G9/AS1 provides guidance for meeting these requirements.

Ventilation

18.1 aluplast® uPVC Windows and Doors contain openable sashes which will contribute to the compliance of building with NZBC Clause G4. Consideration must be given to the 'net openable area' required for a particular space by the designer. NZBC Acceptable Solution G4/AS1 provides guidance on required ventilation.

Natural Light

19.1 aluplast® uPVC Windows and Doors can be used to meet the performance requirements of the NZBC for natural light. NZBC Acceptable Solution G7/AS1 provides guidance for meeting these requirements.

Energy Efficiency

20.1 aluplast® uPVC Windows and Doors supplied with insulated glazing units (IGUs) will assist in meeting the performance requirements of NZBC H1.3.1 and H1.3.2E

20.2 The thermal resistance [R-value] of typical aluplast® uPVC Windows and Doors are given in Table 1. These R-values exceed the minimum thermal resistance of R 0.26 m²K/W required for thermal designs using the Schedule Method of NZS 4218. Contact an aluplast® Agent for R-value calculations for other glazing options.

Table 1: Thermal Resistance

Frame Profile	Reinforcement	Glazing	R value [m ² K/W]
60mm	229119	IGU Classic - Aluminium Spacer	0.37
		IGU Classic - Thermal Spacer	0.38
		Metro Low E Max	0.58
		Metro Low E Excel	0.71
		Planitherm XN™	0.71

Installation Information

Installation Skill Level Requirements

21.1 Where the installation of aluplast® uPVC Windows and Doors requires a building consent, the installation must be carried out by, or under the supervision of, a Licensed Building Practitioner with the relevant licence class in accordance with this Appraisal and the Technical Literature. Where the installation is exempt from requiring building consent, the installation of aluplast® uPVC Windows and Doors must comply with the NZBC and be completed by builders or installers with experience in window and door installation.

Joinery Installation

- 22.1 NK Window Solutions Ltd and Warm Windows provide Technical Literature covering installation details for aluplast® uPVC Windows and Doors. Information may also be obtained from NZBC Acceptable Solution E2/AS1.
- 22.2 The selected underlay must be installed by the building contractor in accordance with the underlay supplier's instructions. Flexible flashing tape must be fitted to the sill and the head/jamb junction in accordance with NZBC Acceptable Solution E2/AS1 Paragraph 9.1.5, prior to installation of aluplast® uPVC Windows and Doors.
- 22.3 The framed opening size must be large enough to give approximately 5 – 7.5 mm clearance all round between the wall framing and the reveal liner. Installation of joinery may be carried out before or after the fixing of the cladding depending on the type of cladding and sealing or flashing system being used.
- 22.4 Sills must be set true and level and jambs plumb before fixing the joinery permanently in place.
- 22.5 Fixings into the supporting framing shall be in accordance with NZBC Acceptable Solution E2/AS1 Paragraph 9.1.10.8 with regard to fixing type and position. Packing must be provided between the joinery reveal and framing or substrate at the point of fixing to set the joinery frame in correct alignment. There must be no vertical or lateral pressures transmitted to the joinery frames from the building structure, cladding or packers. All packers must be in a sound condition suitable for supporting the selected fastener or fixing.
- 22.6 The installation of the joinery and associated flashings must be in accordance with the details provided in NZBC Acceptable Solution E2/AS1 or details of a specific design.
- 22.7 Appropriately specified windows and doors must be installed where required to comply with the requirements of Safety from Falling, Restricting Access to Residential Pools and Human Impact Safety.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests and Investigations

- 23.1 Testing has been carried out on the joinery by an IANZ accredited laboratory and meets the requirements of NZS 4211. This testing covered positive and negative deflection, operating force (static and moving), air infiltration (positive and negative), water penetration, ultimate strength, and torsional strength. Test reports were reviewed by BRANZ experts and found to be satisfactory.
- 23.2 BRANZ durability experts have reviewed overseas test data for aluplast® uPVC and have also considered the history of use of uPVC joinery in New Zealand and overseas.
- 23.3 A weather-tightness opinion has been given by BRANZ experts.
- 23.4 Site inspections have been carried out by BRANZ to assess the practicability of installation of the uPVC joinery systems, and to examine completed installations for use and ease of operation, and long-term durability.



Quality

- 24.1 The manufacture of aluplast® uPVC profiles has not been examined by BRANZ, but details regarding the quality and composition of the materials used were obtained by BRANZ and found to be satisfactory. BRANZ has taken note of RAL Gütezeichen product certification covering quality aspects associated with the product. aluplast® GmbH are also certified to ISO 9001: 2015 by BSI Assurance UK Ltd.
- 24.2 The fabrication of aluplast® uPVC Windows and Doors by NK Window Solutions Ltd and Warm Windows has been examined by BRANZ including methods adopted for quality control and found to be satisfactory.
- 24.3 aluplast® GmbH is responsible for the quality of the supplied uPVC profiles. NK Window Solutions Ltd and Warm Windows are responsible for both the design and quality of the fabricated joinery supplied.
- 24.4 Building designers are responsible for the design of the building, and for the incorporation of the joinery into their design in accordance with this Appraisal.
- 24.5 Installers and glaziers are responsible for the quality of installation in accordance with the installation instructions of NK Window Solutions Ltd and Warm Windows.
- 24.6 Building owners are responsible for the maintenance of the joinery in accordance with this Appraisal. See Paragraphs 11.1 to 11.6.

Sources of Information

- AS/NZS 4666: 2012 Insulating Glass Units
- NZS 3604: 2011 Timber-framed buildings.
- NZS 4211: 2008 Specification for performance of windows.
- NZS 4223.3: 2016 Glazing in Buildings – Part 3: Human impact safety requirements
- NZS 4218: 2009 Thermal insulation – Housing and small buildings
- Compliance Document for New Zealand Building Code External Moisture Clause E2, Department of Building and Housing, Third Edition July 2005 [Amendment 7, 01 January 2017].
- Ministry of Business, Innovation and Employment Record of Amendments for Compliance Documents and Handbooks.
- The Building Regulations 1992.



BRANZ Appraised
Appraisal No. 1005 [2018]

BRANZ Appraisal
Appraisal No. 1005 [2018]
5 November 2018

ALUPLAST® UPVC WINDOWS
AND DOORS

aluplast® Agents in New Zealand



Cascade International Ltd [trading as Warm Windows]
63 Kerwyn Ave
East Tamaki
Auckland
Tel: 09 265 0341
Fax: 09 265 0342
E-mail: info@warmwindows.co.nz



ECO Doors & Windows
29 Hutt Road
Thorndon
Wellington
Tel: 04 974 8930
E-mail: sales@edaws.co.nz
Web: <https://ecowindows.nz/>



NK WINDOWS
uPVC Systems

NK Window Solutions Ltd
8 Anchorage Road
Hornby
Christchurch
Tel: 03 344 3126
Fax: 03 344 3127
Email: info@nkwindows.co.nz
Web: <http://www.nkwindows.co.nz>

Amendments

Amendment No 1, dated 19 November 2018.

This Appraisal has been amended to update Table 1.



BRANZ Appraised
Appraisal No. 1005 [2018]

BRANZ Appraisal
Appraisal No. 1005 [2018]
5 November 2018

ALUPLAST® UPVC WINDOWS
AND DOORS



In the opinion of BRANZ, **aluplast® uPVC Windows and Doors** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **aluplast GmbH**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **aluplast GmbH**:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **aluplast GmbH**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **aluplast GmbH** or any third party.

For BRANZ

Chelydra Percy

Chief Executive

Date of Issue:

5 November 2018