

# **BRANZ Type Test Summary**

**This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of**

**Marlite NZ Ltd.  
80 Henderson Valley Road  
Henderson  
Auckland  
New Zealand**

**Test standard:** ISO 5660:2002

**Specimen name:** Marlite Sanitary Wall Lining S100 S2S (Class A)  
White Smooth Panel

**Specimen description:** Adhesive Marlite Sanitary Wall Lining S100 S2S (Class A) White Smooth Panel adhered to either paper-faced plasterboard, fibre-cement board, plywood or MDF with Marlite C375 Solvent

**Orientation:** Front face is Glossy & has the visual Fibre pattern, back is smooth and Dull finish

**A full description of the test specimen and the test results are given in BRANZ Test Report:**

**Fire Test FH 5310 – Test date 2<sup>nd</sup>, 3<sup>rd</sup> and 10<sup>th</sup> September 2013**

**Regulatory authorities are advised to examine test reports before approving any product.**

**The test results were the basis for the following:**

<b>Building Code Document</b>	<b>Group Number Classification</b>
NZBC Verification Method C/VM2 Appendix A	3

**Issue Date:**

**27 November 2013**

**Expiry Date:**

**27 November 2018**



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.