

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of

Potter Interior Systems
9 McNab Street
Penrose
Auckland 1061
New Zealand

Test standard: ISO 5660 Parts 1 and 2.

Specimen name: K Flex St.

Specimen description: Black closed cell elastomeric foam insulation in nominal thickness between 6 mm and 25 mm.

Orientation: From the direction tested.

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5506-TT – Test dates 31 March, 22 April and 23 April 2014

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	2

Issue Date:
27 May 2014

Expiry Date:
27 May 2019



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation.