

# BRANZ Type Test Summary

**This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of**

Commercial Building Supplies Ltd  
35 Wookey Lane  
Kumeu 0810  
New Zealand

**Test standard:** ISO 5660 Parts 1 and 2.  
**Specimen name:** Rockfon Artic.  
**Specimen description:** White faced rigid Rockwool Panel.  
**Orientation:** From the direction tested.

**A full description of the test specimen and the test results are given in BRANZ Test Report:**

Fire Test FH 5610-TT – Test date 9 October 2014

**Regulatory authorities are advised to examine test reports before approving any product.**

**The test results were the basis for the following:**

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1-S

**Issue Date:** 3 November 2014  
**Expiry Date:** 3 November 2019



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation.