

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of

McLennan Insulation Limited
Unit 3, 14 Petone Avenue
Petone, Wellington
New Zealand

Test standard: ISO 5660 Parts 1 and 2.

Specimen name: Wincell Class 0 Insulation, a closed elastomeric NBR sheet.

Specimen description: Foam product which is nominally 19 mm thick and has a nominal density of 60 kg/m³.

Orientation: From the direction tested.

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5685-TT – Test dates 25 February, 24 March and 10 April 2015

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1

Issue Date:
14 April 2015

Expiry Date:
14 April 2020



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation.