

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of

Jaydex International Ltd
Unit 3C, Marken Place
Glenfield
Auckland
New Zealand

Test standard: ISO 5660 Parts 1 and 2.

Specimen name: SF and Granito rubber covering.

Specimen description: Rubber covering made from natural and synthetic raw materials.

Orientation: From the direction tested.

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5702-TT – Test dates 19 and 24 March 2015

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	3

Issue Date:
30 March 2015

Expiry Date:
30 March 2020



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation.