

BRANZ Type Test Summary

This is to certify that the specimens described below have been tested by BRANZ Ltd on behalf of

National Association of Steel Framed Housing
PO Box 76134
Manakau City
Auckland 2341
New Zealand

Test standard: BRANZ Evaluation Method 6.

Specimen name: Window support system

Specimen description: The Nash window support system is an extruded aluminium support bar fixed to the sill trimmer of a light gauge steel house frame. The system provides gravity load support for a window frame.

A full description of the test specimens and the test results are given in BRANZ Test Report:

ST1093-TT [2016] – dated 12 August 2016

The test results were the basis for the following:

Building Code Document	Weight able to be supported by support system
NZBC Clause B1	83 kg at 3 mm deflection

Issue Date:
12 August 2016

Expiry Date:
12 August 2021