

BRANZ Technical Opinion

Summary

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

InsulPro Manufacturing Ltd.
27 Birmingham Road
Otara
Manukau 3013
Auckland

Test standard: AS ISO 9705 – 2003 and ISO 9705:1993.

Specimen name: InsulPro Mammoth Carpark Panel

Specimen description: Insulpro Mammoth Car Park Panel, a nominally 70 mm thick 2.0 kg/m² polyester panel

Orientation: n/a

A full description of the performance assessment is given in BRANZ Technical Opinion:

FAR 4587-TO [2016] issued 20 June 2016

Regulatory authorities are advised to examine reports before approving any product.

The conclusion of the Technical Opinion provides the following Building Code Classifications:

Building Code Document	Group Number Classification
NCC BCA Specification C1.10 Clause 3 and Specification A2.4 Clause 4	1 SMOGR _{ARC} not more than 100 m ² /s ² x 1000
NZBC Verification Method C/VM2 Appendix A	1–S Smoke Production Rate not more than 5 m ² /s

Issue Date:

20 June 2016

Expiry Date:

20 June 2021