

BRANZ Type Test Summary

This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of

Winstone Wallboards Ltd
37 Felix St.
Penrose
Auckland 1061
New Zealand

Test standard: ISO 5660 Parts 1 and 2

Specimen name: GIB® Quietline™

Specimen description: Perforated Gypsum Plasterboard with Polypropylene cloth backing.

Orientation: From the direction tested.

A full description of the test specimen and the test results are given in BRANZ Test Report:

Fire Test FH 5386-TT – Test date 11th and 22nd October 2013
(Project No. FT5634)

Regulatory authorities are advised to examine test reports before approving any product.

The test results were the basis for the following:

| Building Code Document | Group Number Classification |
|-------------------------------------------|-----------------------------|
| NZBC Verification Method C/VM2 Appendix A | 1 – S |

Issue Date: 24 November 2014 **Expiry Date:** 24 November 2019



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.