

BRANZ Technical Opinion

Summary

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Elephant Plasterboard NZ Ltd
14 Bancroft Crescent
Glendene
Waitakere 0602
New Zealand

Test standard: AS 1530.4-2005

Specimen name: Elephant Plasterboard fire rated wall

Specimen description: Steel framed, loadbearing or non-loadbearing walls lined with 6 mm or thicker James Hardie fibre cement board to one face over James Hardie fire battens, and with cavity insulation of 90 mm thick or greater James Hardie mineral fibre insulation of nominal density 64 kg/m³ and with:
10 mm Elephant Standard plasterboard to the other face for 30 minutes FRR or with;
13 mm Elephant Multiboard to the other face for 60 minutes FRR.

Orientation: Exposed to either face.

A full description of the performance assessment is given in BRANZ Technical Opinion:
FAR 4707 TO [2017] issued 6 April 2017

Regulatory authorities are advised to examine the full technical opinion before approving any product.

Issue Date:
6 April 2017

Expiry Date:
6 April 2022