

BRANZ Technical Opinion

Summary

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Principal Products Ltd
Unit J, 657 Great South Road
Penrose
Auckland 1061

Test standard: AS 1530.4-2005 or AS 1530.4-2014

Specimen name: Inspection Hatch FSC 300

Specimen description: Steel framed inspection hatch up to 300 mm x 300 mm

Installed into the following GIB® fire rated floor/ceiling systems:

60/60/60 - GBCJ 60, GBSC 60a*, GBUC 60, GBDFA 60c, GBDFA 60b & GBSCA 60a

45/45/45 - GBFC 45*, GBCJ 45*, GBUC 45 & GBSCA 45

30/30/30 – GBSJ 30*, GBCJ 30*, GBSC 30*, GBUC 30, GBDFA 30a & GBDFA 30d*

15/15/15 – GBFC 15* & GBUC 15

* The inspection panels must be independently supported from the plasterboard.

Orientation: From the underside only.

A full description of the performance assessment is given in BRANZ Technical Opinion:
FAR 4709 T.O. [2017] issued 29 May 2017

Regulatory authorities are advised to examine the full technical opinion before approving any product.

As per the GIB® fire rated floor/ceiling system up to an FRR of 60/60/60

Issue Date:
29 May 2017

Expiry Date:
29 May 2022