

# BRANZ Type Test Summary

**This is to certify that the specimen described below  
has been tested by BRANZ Ltd on behalf of**

Elephant Plasterboard NZ Ltd  
14 Bancroft Crescent  
Glendene  
Waitakere 0602  
New Zealand

- Test standard:** AS 1530.4:2005 Part 4: Fire resistance tests for elements of construction.
- Specimen name:** Elephant Plasterboard load bearing floor/ceiling system
- Specimen description:** The test specimen consisted of a load bearing floor with timber joists and a suspended ceiling system lined with a single layer of 13 mm Elephant Plasterboard Multiboard. Further details of the tested specimen are contained within the full test report.

**A full description of the test specimen and the test results are given in  
BRANZ Test Report:**

Fire Test FR 3958-TT [2017] – Test date 12<sup>th</sup> December 2008

**Regulatory authorities are advised to examine test reports before approving  
any product.**

## **The test results were as follows:**

Stability	55 minutes	No failure
Integrity	45 minutes	No failure
Insulation	55 minutes	No failure

In accordance with the test standard the fire resistance rating (FRR) of the floor/ceiling system is as follows 45/45/45

**Issue Date:**  
**21 June 2017**

**Expiry Date:**  
**21 June 2022**



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation