

# BRANZ Type Test Summary

**This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of**

Donovan Group NZ Limited  
PO Box 1069  
Whangarei  
New Zealand

**Test standard:** AS 1530.4:2014 Part 4: Fire resistance tests for elements of construction.

**Specimen name:** Modnpanel Construction System

**Specimen description:** The test specimen consisted of a non-loadbearing wall nominally 3,000 mm high x 3,000 mm wide. The wall was constructed from pre-fabricated panels of magnesium sulphate based board, nominally 12 mm thick. The overall depth of the panels was nominally 124 mm and the cavities were filled with 60 kg/m<sup>3</sup> rockwool insulation.

**A full description of the test specimen and the test results are given in BRANZ Test Report:**

Fire Test FR6167-TT[2017] – Test date 18 May 2017

**Regulatory authorities are advised to examine test reports before approving any product.**

**The test results were as follows:**

Integrity	240 minutes
Insulation	166 minutes
FRL	-/240/120

**Issue Date:**  
30 June 2017

**Expiry Date:**  
30 June 2022



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.