

FC10033-001 TO [2018]

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

Raise Lift Group
Unit 1, 28-34 Roseberry Street
Balgowlah
New South Wales, 2093
Australia

Reference BRANZ Reports: FC10033-001 TO [2018]

Relevant Standard AS 1530.4:2014, AS 1735.11:1986

Specimen Name: Doppler two panel, centre opening, lift landing door

Specimen Description: Doppler two panel centre opening lift landing door as tested in FIRES fire resistance test, as described in test report FIRES-FR-191-08-AUNE, with clear opening dimensions:

- 700 mm to 900 mm wide x up to 2,000 mm high
- 1,000 mm wide x up to 2,100 mm high
- 1,100 mm wide x up to 2,200 mm high
- 1,200 mm to 1,400 mm wide x up to 2,400 mm high

Orientation: Exposure from lift landing side

The assessed results were as follows

Integrity 120 minutes

FRL -/120/-

Complies with Clause 2.2.1 of AS 1735.11

Issued by

M.E. Godkin
Senior Fire Testing Engineer
Choose an item.

Reviewed by

E. Soja
Senior Fire Safety Engineer
Choose an item.

Regulatory authorities are advised to examine test reports before approving any product.

Issue Date

9 August 2018

Expiry Date

9 August 2023