

FC10206-001

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

Donovan Group NZ Limited
PO Box 1069
Whangarei
New Zealand

Reference BRANZ Reports FC10206-001

Referenced Standard AS1530.4:2014

Specimen Name: 124 mm thick Modnpanel wall system with timber top and bottom plate

Specimen Description: Pre-fabricated Modnpanel consisting of magnesium sulphate facing with a mineral fibre core incorporating a timber top and bottom plate in each panel.

Orientation: Exposure from either side

The assessed results were as follows

System	FRR
Modnpanel wall system with the top and bottom plate secured at 600 mm centres at mid depth of the plate.	-/90/90

Issued by


Paul Chapman
Senior Fire Testing Engineer
BRANZ

Reviewed by


Ed Soja
Senior Fire Safety Engineer
BRANZ

Regulatory authorities are advised to examine test reports before approving any product.

Issue Date

27 August 2018

Expiry Date

27 August 2023