

FC10936-001

TECHNICAL SUMMARY OPINION



This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Client

Sealed Air (New Zealand)
24 Bancroft Crescent
Glendene
Auckland 0650
New Zealand

Test standard

AS ISO 9705 – 2003 and ISO 9705:1993

Specimen name

60 mm Stratocell® Whisper™ Foam

Specimen description

Sound absorbing polyethylene acoustic foam

Orientation

As tested, fixed to steel framing.

A full description of the performance assessment is given in BRANZ Technical Opinion

FC10936-001 issued 23/09/2019

Regulatory authorities are advised to examine reports before approving any product. The conclusion of the Technical Opinion provides the following Building Code Classifications

Building Code Document	Group Number Classification
NCC BCA Specification C1.10 Clause 4 determined in accordance with AS 5637.1	1 SMOGR _{ARC} not more than 100 m ² /s ² x 1000
NZBC Verification Method C/VM2 Appendix A	1-S Smoke Production Rate not more than 5 m ² /s

Issued by

P C R Collier
P. C. R. Collier
Senior Fire Testing
Engineer
BRANZ

Reviewed by

P N Whiting
P. N. Whiting
Senior Fire Engineer/Fire
Testing Team Leader
BRANZ

Issue Date

23/09/2019

Expiry Date

23/09/2024