

# FC12411-002

## TECHNICAL SUMMARY OPINION



This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

### Test Sponsor

CSR Martini Pty Ltd  
4 Macdonald Road  
Ingleburn  
NSW 2565  
Australia

### Reference BRANZ Technical Opinion

FC12411-002 – issued 17 April 2020

### Test standard

AS ISO 9705 – 2003 and ISO 9705:1993

### Specimen name

dECO 3D Tile Base

### Specimen description

An 8 mm thick, 1,550 gsm, 100% thermally bonded polyester fibre laminated and moulded sound absorptive tile

### Orientation

Underside


**A full description of the performance assessment is given in BRANZ Technical Opinion**

FC12411-002 - issued 17 April 2020


**Regulatory authorities are advised to examine reports before approving any product. The conclusion of the Technical Opinion provides the following Building Code Classifications**

Building Code Document	Group Number Classification
NCC BCA Specification C1.10 Clause 4 determined in accordance with AS 5637.1	1 SMOGR <sub>ARC</sub> not more than 100 m <sup>2</sup> /s <sup>2</sup> x 1000
NZBC Verification Method C/VM2 Appendix A	1-S Smoke Production Rate not more than 5 m <sup>2</sup> /s

### Issued by

  
L. F. Hersche  
Fire Testing Engineer  
BRANZ

### Reviewed by

  
P. N. Whiting  
Senior Fire Engineer/Fire Testing Team  
Leader  
BRANZ

### Issue Date

17 April 2020

### Expiry Date

17 April 2025