

FC10836-001 TO Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

Elephant Plasterboard (NZ) Ltd
14 Bancroft Crescent
Greenlane
Waitakere 0602
New Zealand

Reference BRANZ Reports FC10836-001 TO

Referenced Standard AS1530.4

Specimen Name: Elephant Plasterboard 60 minute wall junction with Comflor concrete floors

Specimen Description: 60 minute steel stud Elephant Plasterboard wall junction detail between the top of the wall and underside of Comflor castellated concrete flooring.

Orientation: Exposure from the underside

The assessed results were as follows:

Up to an FRR of -/60/60

Issued by

A blue ink signature of M. E. Godkin.

M. E. Godkin
Senior Fire Testing Engineer
BRANZ

Reviewed by

A blue ink signature of P. Chapman.

P. Chapman
Senior Fire Testing Engineer
BRANZ

*Regulatory authorities are advised to examine
test reports before approving any product.*

Issue Date

28 May 2020

Expiry Date

28 May 2025