

# FC13372-002 ISSUE 1

## Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

### Sponsor

Winstone Wallboards Limited  
37 Felix Street  
Penrose  
Auckland, 1061  
New Zealand

**Reference BRANZ Reports** FC13372-001 ISSUE 1

**Referenced Standard** EN 13501-1:2018

**Specimen Name:** GIB Weatherline®

**Specimen Description:** 10 mm and 13 mm GIB Weatherline®

**Orientation:** Fire Exposure on either face

### The assessed results were as follows

10 mm and 13 mm GIB Weatherline® can be classified in accordance with EN 13501-1:2018 as:

## Class A1

**Issued by**

A blue ink signature of E. Soja, written in a cursive style.

E. Soja  
Senior Fire Safety Engineer  
BRANZ

**Reviewed by**

A blue ink signature of L. F. Hersche, written in a cursive style.

L. F. Hersche  
Fire Testing Engineer  
BRANZ

Regulatory authorities are advised to examine technical opinion FC13372-001 ISSUE 1 before approving any product.

**Issue Date**

23 September 2020

**Expiry Date**

23 September 2025