

FC13178-001 Issue 1

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

GDR Architectural Limited
127 Diana Drive,
Auckland 0627,
New Zealand

Pacific Door Systems Ltd
17 Meachen Street,
Seaview,
Lower Hutt 5010,
New Zealand

Best Doors Ltd
80 Hastie Avenue,
Mangere Bridge,
Auckland 2022,
New Zealand

Reference BRANZ Reports FC13178-001 Issue 1

Referenced Standard AS 1530.4-2005 or AS 1530.4:2014

Specimen Name: GDR hardware on F0.5 or BP30 30 minute fire rated doorsets

Specimen Description: Record DFA 127 frame mounted door operator and IS9100 frame mounted Swing door operator.

Orientation: Exposure from either side

The assessed results were as follows

Hardware	Doorset	FRR
Record DFA 127	F0.5	-/30/30
Record DFA 127 LEN		
IS9100		
Record DFA 127	BP30	-/30/30
Record DFA 127 LEN		
IS9100		

When installed the hardware and doorset shall comply with NZS 4520:2010

Issued by

A handwritten signature in blue ink, appearing to read "P. Chapman".

P. Chapman
Senior Fire Testing Engineer
BRANZ

Reviewed by

A handwritten signature in blue ink, appearing to read "E. Soja".

E. Soja
Senior Fire Safety Engineer
BRANZ

Regulatory authorities are advised
to examine test reports before
approving any product.

Issue Date

9 October 2020

Expiry Date

9 October 2025