

FI13092-002

GROUP CLASSIFICATION NUMBER



This is to certify that the specimen described below was tested by BRANZ for determination of Group Number Classification and SMOGRA in accordance with AS ISO 9705:2003 (R2016) and Group Number Classification and Smoke Production Rate in accordance with ISO 9705:1993.

Test Sponsor

Asona Limited
Unit 14/7 Cain Road
Penrose
Auckland
New Zealand

Date of test

2 September 2020

Reference BRANZ Test Report

FI13092-001 – issued 14/10/2020

Test specimen as described by the client

The product submitted by the client for testing was identified by the client as Asona Polyfon 45 mm thick, black polyester panel with weight of 1,800 gsm.

Group Number Classification in accordance with NCC Australia

Calculations were carried out as per AS 5637.1:2015. The Group Number Classification and SMOGRA_{RC} for the sample as described above is given in the table below.

Determination of Fire Hazard Properties

The specimen was deemed suitable for testing in accordance with AS 5637.1:2015 and testing was performed in accordance with AS ISO 9705:2003 (R2016) for the purposes of Group Number classification as specified in the NCC Volume One Specification C1.10 Clause 4.

Group Number Classification in accordance with the New Zealand Building Code

Calculations were carried out according to NZBC Verification Method C/VM2 Appendix A. The classification for the sample as described above is given in the table below.

Building Code Document	Group Number Classification
NCC Volume One Specification C1.10 Clause 4 determined in accordance with AS 5637.1:2015	1 The SMOGRA was $3.6 \text{ m}^2/\text{s}^2 \times 1000$ and therefore within the $100 \text{ m}^2/\text{s}^2 \times 1000$ limit
NZBC Verification Method C/VM2 Appendix A	1-S Average Smoke Production Rate was $1.0 \text{ m}^2/\text{s}$ and therefore within the $5 \text{ m}^2/\text{s}$ limit

Issued by

L. F. Hersche
Fire Testing Engineer
IANZ Approved
Signatory

Reviewed by

E. Soja
Senior Fire Safety
Engineer
IANZ Approved Signatory

Regulatory authorities are advised to examine test reports before approving any product



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation

Issue Date

14/10/2020

Expiry Date

14/10/2025