

FC11917-002 ISSUE 1

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

Clay Brick & Paver Manufacturers Association (NZ)
145 Khyber Pass Road
Grafton
Auckland, 1023
New Zealand

Reference BRANZ Reports FC11917-001 ISSUE 1

Referenced Standard AS1530.4-2005 and 2014

Specimen Name: Clay Brick & Paver Manufacturers Association (NZ) members 70 mm, 80 mm, 90 mm, 100 mm or 110 mm thick clay bricks

Specimen Description: 70 mm, 80 mm, 90 mm, 100 mm or 110 mm thick clay bricks used as a veneer on steel or timber framed plasterboard lined walls with an FRR of at Least 60/60/60. The veneer may include weep holes no greater than 0.1 m² in area and must be separated from other weep holes by at least 1.5 m

Orientation: Exposure from either side

The assessed results are as follows

FRR = 60/60/60*

- In conjunction with C/AS2 paragraph 5.4

Issued by

A blue ink signature of E. Soja.

E. Soja
Senior Fire Safety Engineer
BRANZ

Reviewed by

A blue ink signature of P. Chapman.

P. Chapman
Senior Fire Testing Engineer
BRANZ

Regulatory authorities are advised to examine FC11917-001 ISSUE 1 before approving any product.

Issue Date

20 October 2020

Expiry Date

20 October 2025