

FC11711-002 Issue 2

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

MEILLER Aufzugtüren GmbH
Ambossstraße 4,
80997 München,
Germany

Reference BRANZ Reports: FC11711-002 Issue 2

Referenced Standard AS 1530.4-2005/2014

Specimen Name: Meiller two panel, centre opening, lift landing door

Specimen Description: Meiller two panel, centre opening, lift landing door described in fire resistance test report WF Report No. 162898, with modifications to the meeting edges as shown in Figure 3, and to the header as shown in Figure 5 of BRANZ assessment report FC11711-002 Issue 2, would achieve a fire resistance level (FRL) of at least -/120/- in accordance with AS 1530.4-2005/2014 and comply with clause 2.2.1 of AS 1735.11.

This applies to doors with a clear opening size as follows:

700 mm wide to 2,400 mm wide x 1,900 mm high to 2,500 mm high

Orientation: Exposure from lift landing side

The assessed results were as follows

Integrity 120 minutes

FRL -/120/-

Complies with Clause 2.2.1 of AS 1735.11

Issued by

A blue ink signature of E. Soja.

E. Soja
Senior Fire Safety Engineer

Reviewed by

A blue ink signature of M. E. Godkin.

M. E. Godkin
Senior Fire Safety Engineer

Regulatory authorities are advised to examine test reports before approving any product.

Issue Date

22/10/2020

Expiry Date

22/10/2025