

FC13181-002

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor: Pinnacle Rigging 2015 Ltd
196 Broadway Avenue
Palmerston North, 4410
New Zealand

Reference BRANZ Reports: FC13181-001

Referenced Standard: AS 1530.4:2014


Specimen Name: Pinnacle Rigging 50 mm single leaf, side hung 30 minute doorset


Specimen Description: A full description of the test specimen and the test results are given in BRANZ Type Test report FR12658-001 ISSUE 2

Orientation: Exposure from either side

The assessed results were as follows:

FRR -/30/30

Issued by

S. Whatham
Fire Testing Engineer
BRANZ

Reviewed by

E. Soja
Senior Fire Safety Engineer
BRANZ

Regulatory authorities are advised to examine test reports before approving any product.

Issue Date
11 November 2020

Expiry Date
11 November 2025