

FR5760-C1 ISSUE 2

Type Test Summary



This is to certify that the specimen described below has been tested by BRANZ on behalf of the sponsor.

Sponsor: XLAM NZ Limited
60M Surrey Crescent
Auckland 1021
New Zealand

Referenced Standard: AS 1530.4:2014

Specimen Name: XLam NZ Ltd. Cross Laminated Timber Floor

Specimen Description: The floor consisted of two panels and four side pieces of CLT secured together at overlapping joints to form a floor with a span of 3,105 mm and an overall size of 3,500 mm x 3,950 mm. Further details of the tested specimen are contained within the full test report. The report can be supplied directly by XLAM or for verification purposes directly by BRANZ on instruction from XLAM.

A full description of the test specimen and the test results are given in BRANZ Type Test report: FR5760 ISSUE 2


Orientation: Exposure from below

The assessed results were as follows:


Structural adequacy	69 minutes	No failure
Integrity	69 minutes	
Insulation	69 minutes	No failure

The tested specimen is deemed to have achieved an FRL of 60/60/60

Issued by


A. Babb
Fire Testing Engineer
BRANZ

Reviewed by


S. Whatham
Fire Testing Engineer
IANZ Approved Signatory

Regulatory authorities are advised to examine test reports before approving any product.

Issue Date

19 January 2021

Expiry Date

19 January 2026