# FH13362-001-C1 Issue 1 GROUP NUMBER CLASSIFICATION



This is to certify that the specimens described below were tested by BRANZ for determination of Group Number Classification and Average Specific Extinction Area in accordance with ISO 5660 Parts 1 and 2.

**Test Sponsor** 

Asona Limited
Unit 14, 7 Cain Road
Penrose, Auckland 1061
New Zealand

**Date of tests** 

7<sup>th</sup> December 2020

**Reference BRANZ Test Report** 

FH13362-001 Issue 1 - 24 March 2021

# Test specimens as described by the client

## **Asona Gypclean**

Nominally 9 mm thick vinyl faced plasterboard with a foil backing.

Specimen Reference	Mass (g)	Thickness (mm)	Apparent Density (kg/m³)	Colour
FH13362-1-50-2	61.3	9.1	674	White
FH13362-1-50-3	61.9	9.1	680	White
FH13362-1-50-4	62.4	9.0	693	White

## Group Number Classification in accordance with the New Zealand Building Code

Calculations were carried out according to NZBC Verification Method C/VM2 Appendix A. The classification for the sample as described above is given in the table below.

## **Group Number Classification in accordance with NCC Australia**

Calculations were carried out according to AS 5637.1:2015. The Group Number Classification and Average Smoke Extinction Area for the sample as described above is given in the table below.

## **Determination of Fire Hazard Properties**

The specimen was deemed suitable for testing in accordance with AS 5637.1:2015 and testing was performed in accordance with ISO 5660 for the purposes of Group Number Classification as specified in the NCC Volume One Specification C1.10 Clause 4.

Building Code Document	Group Number Classification	
NZBC Verification Method C/VM2 Appendix A	1-S	
NCC Volume One Specification C1.10 Clause 4 determined in accordance with AS 5637.1:2015	1 The average specific extinction area was <b>less</b> than the 250 m2/kg limit	

Issued by

J. R. Stallinger Associate Fire Testing Engineer BRANZ

> Issue Date 24 March 2021

Reviewed by

L. F. Hersche Fire Testing Engineer IANZ Approved Signatory

> Expiry Date 24 March 2026

Regulatory authorities are advised to examine test reports before approving any product.



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation