

# FC13181-002 Issue 2

## Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

**Sponsor:** Pinnacle Rigging 2015 Ltd  
196 Broadway Avenue  
Palmerston North, 4410  
New Zealand

**Reference BRANZ Reports:** FC13181-001 ISSUE 2

**Referenced Standard:** AS 1530.4-2005/2014

**Specimen Name:** Pinnacle Rigging 50 mm single leaf, side hung 30 minute doorset

**Specimen Description:** A full description of the test specimen and the test results are given in BRANZ Type Test report FR12658-001 ISSUE 2

**Orientation:** Exposure from either side

**The assessed results were as follows:**

FRR -/30/30

**Issued by**

A handwritten signature in blue ink, appearing to read "S. Whatham".

S. Whatham  
Fire Testing Engineer  
BRANZ

**Reviewed by**

A handwritten signature in blue ink, appearing to read "E. Soja".

E. Soja  
Senior Fire Safety Engineer  
BRANZ

Regulatory authorities are advised to examine test reports before approving any product.

**Issue Date**

7 April 2021

**Expiry Date**

7 April 2026