

FC13639-001-C2 Issue 1

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

CSR Building Products (NZ) Ltd
PO Box 17220
Greenlane
Auckland 1546
New Zealand

Reference BRANZ Reports: FC13639-001 Issue 1

Referenced Standard: AS1530.4-2005/2014

Specimen Name: Winstone Wallboards Limited GIB® fire rated floor/ceiling systems with CSR Hebel 75 mm Powerfloor.

Specimen Description: Fire rated floor/ceiling systems with CSR Hebel 75 mm thick Powerfloor flooring panel with Winstone Wallboards Limited GIB® fire rated ceiling lining.


Orientation: Exposure from the underside

The assessed results were as follows:

FRR	GIB® system
15/15/15	GBFC 15, GBUC 15
30/30/30	GBFC 30, GBCJ 30, GBSJ 30, GBSC 30, GBUC 30, GBDFA 30a or GBDFA 30d
45/45/45	GBFC 45, GBCJ 45, GBSJA 45 or GBSCA 45
60/60/60	GBFC 60, GBCJ 60, GBSJ 60, GBSC 60a, GBSC 60b, GBUC 60, GBDFA 60b, GBDFA 60d, GBDFA 60e, GBSJA 60 or GBSCA 60a
90/90/90	GBFC 90, GBSC 90 or GBUC 90
120/120/120	GBFC 120 or GBUC 120

* Refer to the Winstone Wallboards Ltd GIB® Fire Rated Systems Specification and installation manual (October 2018) or *GIB® Noise Control Systems Specification and installation manual (September 2017)* for the plasterboard installation details.

Issued by


P. Chapman
Senior Fire Testing Engineer
BRANZ

Reviewed by


E. Soja
Senior Fire Safety Engineer
BRANZ

Regulatory authorities are advised to examine the Technical Opinion report FC13639-001 before approving any product.

Issue Date

4 March 2021

Expiry Date

4 March 2026