

FH14001-001-C1 ISSUE 1

GROUP NUMBER CLASSIFICATION



This is to certify that the specimens described below were tested by BRANZ for determination of Group Number Classification and Average Specific Extinction Area in accordance with ISO 5660 Parts 1 and 2.

Test Sponsor

MM Collection Ltd T/A Emma Hayes
68 Cameron St
Onehunga
Auckland, 1061
New Zealand

Date of tests

28th April 2021

Reference BRANZ Test Report

FH14001-001 ISSUE 1 – issued 16 June 2021

Test specimens as described by the client

Dreamscape Vinyl Pearl Printed Wallcovering

An embossed vinyl face with a metallic/pearlescent sheen and a laminated non-woven backing, printed with water-based inks. The product was adhered to a nominal 10 mm thick paper faced plasterboard with Roman Pro-774 Clay Strippable Wallcovering Adhesive.

Specimen Reference	Mass (g)	Thickness (mm)	Apparent Density (kg/m ³)	Colour
FH14001-1-50-1	69.7	10.4	670	Blue
FH14001-1-50-2	70.2	10.4	675	Blue
FH14001-1-50-3	69.7	10.3	677	Blue

Group Number Classification in accordance with the New Zealand Building Code

Calculations were carried out according to NZBC Verification Method C/VM2 Appendix A. The classification for the sample as described above is given in the table below.

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	2-S

Issued by

J. Stallinger
Associate Fire Testing Engineer
BRANZ

Reviewed by

L. F. Hersche
Fire Testing Engineer
IANZ Approved Signatory

Regulatory authorities are advised to examine test reports before approving any product.



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation

Issue Date

16 June 2021

Expiry Date

16 June 2026