FC12740-001 C1 Issue 2 Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

Winstone Wallboards Limited 37 Felix Street Penrose Auckland, 1061 New Zealand

Reference BRANZ Reports FC12740-001 Issue 2

Referenced Standard AS 1530.4-2005 and AS 1530.4:2014

Specimen Name: GIB Fire Soundseal® sprinkler pipe, cable penetrations and linear gap seals.

Specimen Description: Sprinkler pipe and cable penetrations as shown in Figure 1, Figure 2 and Figure 3. Linear gap seals filled with GIB Fire Soundseal[®]

Orientation: Fire Exposure from underside of floor/ceiling systems and either side of wall systems.

The assessed results were as follows:

Sprinkler ceiling penetration shown in Figure 1 and the cables penetrations shown in Figure 2 and Figure 3, using GIB Fire Soundseal®, would not be detrimental to the fire resistance, in accordance with AS 1530.4-2005/2014, of any Winstone Wallboards fire rated wall or floor/ceiling system as appropriate to the penetration.

It is considered that linear gap seals up to a maximum of 10 mm wide, backed by framing and filled to the full depth of the lining with GIB Fire Soundseal® would maintain the Integrity and Insulation criteria in accordance with AS 1530.4-2005/2014 of the wall up to a maximum of 120 minutes.

Issued by

P. Chapman
Senior Fire Testing Engineer
BRANZ

Issue Date 17 May 2021 Reviewed by

Senior Fire Safety Engineer BRANZ

> Expiry Date 17 May 2026

Regulatory authorities are advised to examine the Technical Opinion report FC12740-001 Issue 2 before approving any product.

Figure 1: Sprinkler pipe penetration (ceiling)




Figure 2: Single and looped cable penetration (ceiling)

Figure 2a Figure 2b




Figure 3: Single and looped cable penetration (wall)

