

# **FAR 4527-C1 Issue 2**

## **Technical Opinion Summary**



This is to certify that the specimen described below has been examined by  
BRANZ on behalf of the sponsor.

**Sponsor:**

CSR Martini Pty Ltd  
4 Macdonald Road  
Ingleburn  
NSW 2565  
Australia

**Reference BRANZ Reports :**

FAR 4527 Issue 2

**Referenced Standard(s):**

AS ISO 9705 – 2003 and ISO 9705:1993

**Specimen Name:**

Ecooustic 3D Wall and Ceiling Tile

**Specimen Description:**

An 8 mm thick 1550 gsm 100% polyester fibre laminated and moulded sound absorptive tile.

**Orientation:**

Underside

**The assessed results are as follows:**

Building Code Document	Group Number Classification
NCC BCA Specification C1.10 Clause 4 determined in accordance with AS 5637.1	1 SMOGR <sub>ARC</sub> not more than 100 m <sup>2</sup> /s <sup>2</sup> x 1000
NZBC Verification Method C/VM2 Appendix A	1-S Smoke Production Rate not more than 5 m <sup>2</sup> /s

Regulatory authorities are advised to examine FAR 4527 Issue 2 before approving any product

**Issued by:**

A handwritten signature in blue ink, appearing to read "L. F. Hersche".

L. F. Hersche  
Fire Testing Engineer  
BRANZ

**Reviewed by:**

A handwritten signature in blue ink, appearing to read "E. Soja".

E. Soja  
Senior Fire Safety Engineer  
BRANZ

**Issue date:**

15 September 2021

**Expiry date:**

15 September 2026