

# FC11824-02 C1 Issue 1

## Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

### Sponsor

Hiandri Solutions Limited  
PO Box 3026  
Hawkes Bay Mail Centre  
Napier, 4142  
New Zealand

**Reference BRANZ Reports** FC11824-02 Issue 2

**Referenced Standard** AS1530.4:2014

**Specimen Name:** GIB® Fire Rated Timber Framed Wall Systems with Hiandri packer system


**Specimen Description:** Winstone Wallboards Limited fire rated timber wall systems with the Hiandri packer system consisting of a Hiandri packer, 9 mm thick plywood, polyurethane expanding foam and GIB Fire Soundseal® installed with the following GIB® systems:

GIB® system	FRR
GBUW 15	15/15/15
GBTL30, GBTL 30b, GBTL 30c, GBUW 30a, GBUW 30b, GBTLA 30a, GBTLA 30b, GWTLE 30 or GWTLP 30	30/30/30
GBTL 60GBTL 60b, GBUW 60, GBTLAB 60a*, GBTLAB 60b*, GBTLAB 60c*, GBTLAB 60d*, GBTLA 60, GWTLE 60a, GWTLE 60b or GWTLP 60	60/60/60
GBTL 90, GBUW 90, GBTLA 90c or GBTLA 90d	90/90/90
GBT 120a or GBT 120b	-/120/120
GBTL 120 or GBUW 120,	120/120/120

\* These systems do not require the plywood packer.

**Orientation:** Two way walls - Exposure from either face  
One way walls (universal walls) – Exposure from the plasterboard face only

**Issued by**

  
P. Chapman  
Senior Fire Testing Engineer  
BRANZ

**Reviewed by**

  
E. Soja  
Senior Fire Safety Engineer  
BRANZ

Regulatory authorities are advised to examine the Technical Opinion report FC11824-02 Issue 2 before approving any product.

**Issue Date**

8 December 2021

**Expiry Date**

8 December 2026