

FAR4378-01-3-C1

TECHNICAL OPINION SUMMARY



This is to certify that the products described below have been examined by BRANZ Ltd on behalf of

Test Sponsor

CSR Martini Pty Ltd
4 Macdonald Road, Ingleburn,
NSW 2565, Australia

Reference BRANZ Report

FAR 4378-01-3 – issued 11/03/2022

Test standards

AS ISO 9705 – 2003 and ISO 9705:1993

Products

Absorb range	MAB range	Soffit range
CSR Martini Absorb XXHD 50mm	CSR Martini MAB 60/50mm	CSR Martini Soffit XXHD 50mm
CSR Martini Absorb XHD 50mm	CSR Martini MAB 48/50mm	CSR Martini Soffit XHD 50mm
CSR Martini Absorb HD 50mm	CSR Martini MAB 32/50mm	
CSR Martini Absorb MD 50mm	CSR Martini MAB 25/50mm	

Description of products

100% thermally bonded white coloured polyester fibre sound absorptive panels with density ranges from 60 kg/m³ down to 25 kg/m³

Orientation

As tested, base adhered to non-combustible substrate

A full description of the performance assessment is given in BRANZ Technical Opinion

FAR 4378-01-3 issued 11/03/2022

Regulatory authorities are advised to examine reports before approving any product. The conclusion of the Technical Opinion provides the following Building Code Classifications

Building Code Document	Group Number Classification
NCC BCA Specification C1.10 Clause 4 determined in accordance with AS 5637.1	1 SMOGR _{ARC} not more than 100 m ² /s ² x 1000
NZBC Verification Method C/VM2 Appendix A	1–S Smoke Production Rate not more than 5 m ² /s

Issued by


L. F. Hersche
Fire Testing Engineer
IANZ Approved Signatory

Reviewed by


E. Soja
Senior Fire Safety Engineer
IANZ Approved Signatory

Issue Date

11/03/2022

Expiry Date

11/03/2027