

FC15787-01

TECHNICAL OPINION SUMMARY



This is to certify that the specimen described below has been examined by
BRANZ Ltd on behalf of

Test Sponsor

CSR Martini Pty Ltd
4 Macdonald Road, Ingleburn,
NSW 2565, Australia

Reference BRANZ Test Report

FC15787-01 – issued 7/04/2022

Test standards

AS ISO 9705 – 2003
ISO 9705:1993

Specimen names

CSR Martini Absorb XHD 75 mm
CSR Martini Soffit XHD 75 mm

Specimen description

Thermally bonded white coloured polyester fibre panels of
thickness 75 mm and 48 kg/m³ density.

Orientation

As tested, base adhered to substrate.

**A full description of the performance assessment is given in
BRANZ Technical Opinion**

FC15787-01 issued 7/04/2022

Regulatory authorities are advised to examine reports before approving any product. The
conclusion of the Technical Opinion provides the following Building Code Classifications.

Building Code Document	Group Number Classification
NCC BCA Specification C1.10 Clause 4 determined in accordance with AS 5637.1	1 SMOGR _{RC} not more than 100 m ² /s ² x 1000
NZBC Verification Method C/VM2 Appendix A	1-S Smoke Production Rate not more than 5 m ² /s

Issued by

L. F. Hersche
Fire Testing Engineer
BRANZ

Reviewed by

E. Soja
Senior Fire Safety Engineer
BRANZ

Issue Date

7/04/2022

Expiry Date

7/04/2027