

# BRANZ Type Test Summary

**This is to certify that the specimen described below has been tested by BRANZ Ltd on behalf of**

Metallink Limited  
RM 217, 21-39 Jellicoe Road  
Panmure, Auckland 1072  
New Zealand

**Test standard:** AS/NZS 2699.1:2000.

**Specimen name:** Metallink Brick Veneer ties (4 Types)

**Specimen description:** Metallink Brick Veneer ties to connect brick veneer to a substrate with following details:

Tie Length (mm)	Material & Description	Veneer Thickness	Classification
85	Hot dipped galvanised steel, 1.3 mm thick & 22 mm wide	70	EL
105	Hot dipped galvanised steel, 1.3 mm thick & 22 mm wide	70	EL
85	4-hole flat end galvanised steel, 1.2 mm thick & 23.5 mm wide	70	EM
85	3-hole rippled end galvanised steel, 1.2 mm thick & 23.5 mm wide	70	EM

**A full description of the test specimens and the test results are given in BRANZ Test Reports:**

ST1025-TT [2014] – dated 24 September 2014

**The test results were the basis for the following:**

Building Code Document	Tie Rating
NZBC Acceptable Solution E2/AS1 Table 18A	EL (2 Types) EM (2 Types)

**Issue Date:**

**21 April 2022**

**Expiry Date:**

**21 April 2027**