

BRANZ Type Test Summary

**This is to certify that the specimen described below
has been tested by BRANZ Ltd on behalf of**

Metallink Limited
RM 217, 21-39 Jellicoe Road
Panmure, Auckland 1072
New Zealand

Test standard: AS/NZS 2699.1:2000.

Specimen name: Metallink Brick Veneer tie

Specimen description: Metallink Brick Veneer ties to connect brick veneer
to a substrate with following details:

| Tie Length (mm) | Material & Description | Classification |
|--------------------|---|----------------|
| 110 | Stainless steel, 1.2 mm thick & 23 mm wide | EM |

**A full description of the test specimens and the test results are given in
BRANZ Test Report:**

ST1025.3-TT [2015] – dated 15 January 2015

The test results were the basis for the following:

| Building Code Document | Tie Rating |
|---|------------|
| NZBC Acceptable Solution E2/AS1 Table 18A | EM |

Issue Date:
21 April 2022

Expiry Date:
21 April 2027