

BRANZ Type Test Summary

This is to certify that the specimens described below have been tested by BRANZ Ltd on behalf of

Metallink Limited
RM 217, 21-39 Jellicoe Road
Panmure, Auckland 1072
New Zealand

Test standard: AS/NZS 2699.1:2000.

Specimen name: Metallink Brick Veneer tie

Specimen description: Metallink Brick Veneer ties to connect brick veneer to a timber substrate with following details:

| Designation | Length (mm) | Material & Description | Classification |
|-------------|-------------|--|----------------|
| Design 4 | 110 | Galvanised, 1.42 mm thick, 23 mm wide | EM |
| Design 5 | 110 | Galvanised, 1.3 mm thick, 23 mm wide | EM |
| Design 6 | 85 | Stainless Steel, 1.12 mm thick, 22.4 mm wide | EL |
| Design 7 | 85 | Stainless Steel, 1.13 mm thick, 23 mm wide | EL |
| Design 8 | 85 | Stainless Steel, 1.13 mm thick, 22 mm wide | EM |

A full description of the test specimens and the test results are given in BRANZ Test Report:

ST1025.4-TT [2015] – dated 22 April 2022

The test results were the basis for the following:

| Building Code Document | Tie Rating |
|---|------------------------------|
| NZBC Acceptable Solution E2/AS1 Table 18A | EM (3 Types) EL (2 Types) |

Issue Date:
22 April 2022

Expiry Date:
21 April 2027