

FAR4516-C1 Issue 3

Technical Opinion Summary



This is to certify that the specimen described below has been examined by BRANZ on behalf of the sponsor.

Sponsor

Smooth-Air Products Limited
264 Annex Road
Riccarton
Christchurch 8024
New Zealand

Reference BRANZ Reports FAR 4516 Issue 3

Referenced Standard AS1530.4:2014

Specimen Name: Halton FDR Fire dampers

Specimen Description:

Halton FDR fire dampers with a maximum profile size of 1,000 mm x 1,000 mm installed in concrete or masonry walls or concrete floors, or insulated steel stud plasterboard walls, or insulated timber stud plasterboard walls.

Orientation: Exposure from either side

The assessed results were as follows:

Fire Resistance Level -/120/120

A handwritten signature in blue ink, appearing to read "P. Chapman".

Issued by

P. Chapman
Senior Fire Testing Engineer
BRANZ

A handwritten signature in blue ink, appearing to read "E. Soja".

Reviewed by

E. Soja
Senior Fire Safety Engineer
BRANZ

Regulatory authorities are advised
to examine FAR 4516 Issue 3
before approving any product.

Issue Date
15 July 2022

Expiry Date
15 July 2027