

FH16556-01-1-C1

GROUP NUMBER CLASSIFICATION



This is to certify that the specimen described below was tested by BRANZ for determination of Group Number classification in accordance NZBC Verification Method C/VM2.

Test Sponsor

CSR Limited
376 Victoria Street
Wetherill Park, NSW 2164
Australia

Date of tests

13th and 21st March 2017

Reference BRANZ Test Report

FH16556-01-1 – 7 September 2022

Test specimens as described by the client

Territory™

A fibre cement panel in various colours and surface patterns.

Sample ID	Mass (g)	Thickness (mm)	Apparent density (kg/m ³)	Colour
FH6140-1-50-1	217.3	16.2	1341	Cream
FH6140-2-50-1	186.3	15.3	1218	Ebony

Group Number Classification in accordance with the New Zealand Building Code

Calculations were carried out according to NZBC Verification Method C/VM2 Appendix A. The classification for the sample as described above is given in the table below.

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1-S

Issued by

L. F. Hersche
Fire Testing Engineer
IANZ Approved Signatory

Reviewed by

E. Soja
Senior Fire Safety Engineer
IANZ Approved Signatory

Regulatory authorities are advised to examine test reports before approving any product.



All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation

Issue Date

7 September 2022

Expiry Date

7 September 2027