FI14361-01-C1 GROUP NUMBER CLASSIFICATION



This is to certify that the specimen described below was tested by BRANZ for determination of Group Number

Classification, Smoke Production Rate and SMOGRA_{RC} in accordance with AS ISO 9705:2003 (R2016) and ISO 9705:1993.

Test Sponsors

Pirmax Pty Ltd 9/170 Boundary Rd Braeside, 3195 Victoria Australia

Date of test:

29 September 2021

Reference BRANZ Test Report:

FI14361-01-1 - issued 11/11/2021

Test specimen as described by the client:

Pirmax ISO2 Panel

100 mm thick 35 kg/m³ polyisocyanurate thermoset foam insulation panel with embossed silver foil facing to the front and back faces.

Group Number classification in accordance with NCC Australia

Calculations were carried out as per AS 5637.1:2015. The Group Number classification and SMOGRA_{RC} for the sample as described above is given in the table below.

Determination of Fire Hazard Properties

The specimen was deemed suitable for testing in accordance with AS 5637.1:2015 and testing was performed in accordance with AS ISO 9705:2003 (R2016) for the purposes of Group Number classification as specified in the NCC Volume One Specification C1.10 Clause 4. This test comprised three walls and the ceiling lined with the test specimen.

Group Number classification in accordance with the New Zealand Building Code

Calculations were carried out according to NZBC Verification Method C/VM2 Appendix A. The classification for the sample as described above is given in the table below.

Building Code Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	2-S
NCC Volume One Specification C1.10 Clause 4 determined in accordance with AS 5637.1:2015	$\label{eq:2} Z$ The SMOGRA $_{RC}$ was 28.8 m^2/s^2x 1000 and therefore within the 100 m^2/s^2x 1000 limit

Issued by

L. F. Hersche Fire Testing Engineer IANZ Approved Signatory

Issue Date 11/11/2021

Reviewed by

S. Whatham Fire Testing Engineer BRANZ

Expiry Date 11/11/2026

Hac-MRA

ACCREDITED

All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation

Regulatory authorities are advised to examine test reports before approving any product.