

FH5999-01-2-C1

GROUP NUMBER CLASSIFICATION



This is to certify that the specimen described below was tested by BRANZ in accordance with ISO 5660 Parts 1 and 2.

Test Sponsor

Rockcote Resene Ltd T/A Resene
Construction Systems
5 Venture Place, Middleton
Christchurch, 8024
New Zealand

Date of tests

11 August and 12 October 2016

Reference BRANZ Test Report

FH5999-01-2 – issued 17 July 2024

Test specimen as described by the client

Rockcote Marrakesh; nominally 11 mm thick polished lime/clay plaster on a plasterboard substrate, and **Rockcote Otsumigaki**; nominally 16 mm thick polished lime/clay plaster on a plasterboard substrate

Classification in accordance with the New Zealand Building Code

Calculations were carried out according to NZBC Verification Method C/VM2 Appendix A. The classification for the sample as described above is given in the table below.

Classification Document	Group Number Classification
NZBC Verification Method C/VM2 Appendix A	1-S

Regulatory authorities are advised to examine test reports before approving any product.

Issued by

A handwritten signature in blue ink, appearing to read "L. F. Hersche".

L. F. Hersche
Fire Testing Engineer
IANZ Approved Signatory

Reviewed by

A handwritten signature in blue ink, appearing to read "Lester Grieve".

Lester Grieve
Fire Testing Engineer
BRANZ



Issue Date

17 July 2024

All tests and procedures reported herein, unless indicated, have been performed in accordance with the laboratory's scope of accreditation