



BRANZ Appraised

Appraisal No. 1103 [2024]

SIKA SIKATITE WPU EXTERIOR

Appraisal No. 1103 [2024]

This Appraisal replaces BRANZ
Appraisal No. 1103 [2019]



BRANZ Appraisals

Technical Assessments of products
for building and construction.



Sika Australia Pty Ltd

55 Elizabeth Street
Wetherill Park
NSW, 2164
Australia

Tel: +61 2 9725 1145

Email: au.marketing@au.sika.com

Web: aus.sika.com



BRANZ

BRANZ

1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908
Porirua 5240,
New Zealand
Tel: 04 237 1170
branz.co.nz



Product

- 1.1 Sika Sikatite WPU is a liquid-applied waterproofing membrane for use under ceramic or stone tile finishes on external decks and balconies.

Scope

- 2.1 Sika Sikatite WPU has been appraised for use as a waterproofing membrane for pedestrian decks and balconies within the following scope:
- on substrates of plywood or compressed fibre cement sheet on timber-framed construction; or,
 - on substrates of concrete; and,
 - when protected from ultraviolet (UV) exposure and physical damage by ceramic or stone tiles; and,
 - where decks and balconies are designed and constructed such that deflections do not exceed 1/360th of the span.
- 2.2 The structural and weathertightness design for each specific structure is the responsibility of the building designer.
- 2.3 The ceramic or stone tile finishes are outside the scope of this Appraisal.
- 2.4 Installation of Sika Sikatite WPU and accessories must be carried out by trained installers, approved by Sika Australia Pty Ltd.

Building Regulations

National Construction Code (NCC)

- 3.1 In the opinion of BRANZ, Sika Sikatite WPU, if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet the following provisions of the NCC:

NCC 2022 Volume One - Building Code of Australia

Part F2 DAMP AND WEATHERPROOFING: Performance F2P2. Sika Sikatite WPU meets this requirement. See Paragraphs 13.1–13.7

NCC 2022 Volume Two - Building Code of Australia

Part H2 DAMP AND WEATHERPROOFING: Performance H2P2. Sika Sikatite WPU meets this requirement. See Paragraphs 13.1 – 13.7

Technical Specification

- 4.1 Materials supplied by Sika Australia Pty Ltd are as follows:
- **Sika Sikatite WPU** – a flexible [Class III as defined in AS/NZS 4858], single-pack, water-based polyurethane waterproofing membrane. It is supplied as a grey paste in 15 L pails.
 - **Eco Prime WB** – an acrylic based multi-purpose primer for all porous substrates.
 - **Eco Prep'N'Prime** – a flexible, one-component primer/bond enhancer for use over difficult or non-porous substrates.

Handling and Storage

- 5.1 All materials must be stored inside, up off concrete floors, in dry conditions, out of direct sunlight and out of freezing conditions. The materials in the original unopened packaging have a shelf life of 12 months from date of manufacture. Once opened, the materials must be used.

Technical Literature

- 6.1 This Appraisal must be read in conjunction with:
- Product Data Sheet – Sika Tite WPU, dated November 2019.
- 6.2 All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

- 7.1 Sika Sikatite WPU is for use where impervious waterproof membranes are required on decks and balconies to prevent damage to building elements and adjoining areas.
- 7.2 The membranes must be covered with ceramic or stone tile finishes within 14 days. The finishes must protect the membrane from exposure to UV light and physical damage.
- 7.3 Movement and control joints may be required depending on the shape and size of the deck and the tiling finish. Design guidance can be found in the BRANZ Good Practice Guide: Tiling.
- 7.4 Effective control of moisture in the structure and from within the building must be considered due to the impermeability of the membrane.
- 7.5 Where the system abuts cladding systems, designers must detail the junction to meet their own requirements and the performance requirements of the NCC. Details not included within the Technical Literature have not been assessed and are outside the scope of this Appraisal.

Substrates

Fibre Cement Compressed Sheet

- 8.1 Fibre cement compressed sheet must be manufactured to comply with the requirements of AS/NZS 2908.2 and must be specified by the manufacturer as being suitable for use as an external decking substrate. The fibre cement sheet must be of a thickness to meet specific structural design requirements and must be secured to the structure to resist wind uplift and all other forces acting on the deck or balcony, such as deflection from gravity and live loads. Installation must be in accordance with the instructions of the manufacturer.

Concrete

- 8.2 Concrete substrates must be to a specific engineering design meeting the requirements of the NCC.

Durability

Serviceable Life

- 9.1 Sika Sikatite WPU, when subjected to normal conditions of environment and use, are expected to have a serviceable life of at least 15 years and be compatible with ceramic or stone tile finishes with a design serviceable life of 15–25 years. This is conditional on the membranes not being exposed to the weather or UV light for a total of more than 14 days.

Maintenance

- 10.1 No maintenance of the membrane will be required provided significant substrate movement does not occur and the tiling finish remains intact. Regular checks must be made of tiled areas to ensure they are sound and will not allow moisture to penetrate. Any cracks or damage must be repaired immediately by repairing the tiles, grout and sealants.
- 10.2 In the event of damage to the waterproofing membrane, the tiling must be removed. Repair can be carried out by applying a patch of suitable membrane.
- 10.3 Drains and outlets must be maintained to operate effectively, and tiling finishes must remain clean.

Outbreak of Fire

- 11.1 Sika Sikatite WPU must be protected or separated from fireplaces, heating appliances, chimneys and flues in accordance with the requirements of NCC Volume One, Performance G2P1, and NCC Volume Two, Deemed-to-Satisfy Provision H7D5 and Performance H7P3.

Spread of Fire

- 12.1 Sika Sikatite WPU is considered an exempt building material, as listed in NCC Specification C2D11.

External Moisture

- 13.1 Decks and balconies must be designed and constructed to meet code compliance with NCC Volume One, Performance F3P1 and NCC Volume Two, Performance H2P2. They must also take account of snowfalls in snow prone areas.
- 13.2 When installed in accordance with this Appraisal and the manufacturer's Technical Literature, Sika Sikatite WPU will prevent the penetration of water and will therefore meet code compliance with NCC Volume One, Performance F3P1 and Volume Two, Performance H2P2. The membrane is impervious to water and will give a weathertight deck capable of accepting minor structural movements.
- 13.3 Sika Sikatite WPU is impermeable, therefore a means of dissipating construction moisture must be provided in the building design and construction to meet code compliance with NCC Volume One, Performance F3P1 and NCC Volume Two, Performance H2P2.
- 13.4 BRANZ recommends a minimum fall to decks and balconies of 1:40 and that all falls must slope to an outlet. Inadequate falls will allow moisture to collect and increase the risk of deterioration of the membrane and tile finish.
- 13.5 Deck and balcony falls must be built into the substrate and not created with mortar screeds applied over the membranes.
- 13.6 Allowance for deflection and settlement of the substrate must be made in the design of the deck or balcony.
- 13.7 Drainage flanges must be used for any outlet and must be fitted with a grate or cage to reduce potential sources of blockages. An overflow must be provided where the deck or balcony does not drain to an external gutter.

Installation Information

Installation Skill Level Requirements

- 14.1 Installation and finishing of materials supplied by Sika Australia Pty Ltd must be completed in accordance with the Technical Literature by trained applicators, approved by Sika Australia Pty Ltd.
- 14.2 Installation of substrates must be completed by tradespersons with a thorough understanding of deck and balcony construction, in accordance with instructions given within the substrate manufacturer's Technical Literature and this Appraisal.

Preparation of substrates

- 15.1 Substrates must be dry and sound before installation proceeds. Concrete slabs can be checked for dryness by using a hygrometer. The relative humidity of the concrete surface must be 75% or less, and the moisture content for plywood must be a maximum of 20%, before laying the membrane.
- 15.2 Surfaces must be smooth and free from sharp edges, dust, dirt or other materials such as oil, grease or concrete formwork release agents. All surface defects must be filled to achieve a smooth and uniform surface.
- 15.3 Substrates must be primed with primer and allowed to dry fully before the membrane is installed.

Membrane Installation

- 16.1 Installation must not be undertaken where the substrate surface temperature is below 5°C or above 35°C.
- 16.2 The membrane must be applied in a minimum of two coats at the rates set out in the Technical Literature to give a total finished thickness of 0.6 mm for walls, 0.8 mm for floors. Subsequent coats must be applied at an opposite direction to the previous coat.
- 16.3 Application can be made by roller [medium/long nap] or brush [long bristle].
- 16.4 It is strongly recommended that the membrane is protected with temporary covers until it is fully cured in case of mechanical damage or rain wetting.
- 16.5 Clean up may be undertaken with water while the membrane is still wet.

Tiling

- 17.1 The membrane must be fully cured before tiling. The cured membrane must be protected at all times to prevent mechanical damage, so may require temporary covers until the finishing is completed.
- 17.2 Tiling must be undertaken in accordance with AS 3958.1 and the BRANZ Good Practice Guide: Tiling. The compatibility of tile adhesive must be confirmed with the adhesive manufacturer or Sika Australia Pty Ltd

Inspections

- 18.1 Critical areas of inspection for waterproofing systems are:
 - Construction of substrates, including crack control and installation of under flashings and movement control joints.
 - Moisture content of the substrate prior to the application of the membranes.
 - Acceptance of the substrate by the membranes installer prior to application of the membrane.
 - Installation of the membranes to the manufacturer's instructions, particularly installation to the correct thickness and use of reinforcement.
 - Membrane curing and integrity prior to the installation of tiles, including protection from moisture, frost and mechanical damage during curing.

Health and Safety

- 19.1 Additional information on Sika Sikatite WPU and accessories is available in the Material Safety Data Sheets available from Sika Australia Pty Ltd

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

- 20.1 The testing on Sika Sikatite WPU has been undertaken by various organisations:
- Testing to AS/NZS 4858:2004 Appendix A including effect of heat aging, bleach, detergent and water on tensile and elongation, Water Vapour Transmission to ASTM E96-92 and cyclic movement.
 - Adhesion to various substrates and low temperature flexibility.
- Test methods and results were reviewed by BRANZ and found to be satisfactory.

Other Investigations

- 21.1 An assessment was made of the durability of Sika Sikatite WPU by BRANZ technical experts.
- 21.2 Site visits have been carried out by BRANZ to assess the practicability of installation, and to examine completed installations.
- 21.3 The Technical Literature has been examined by BRANZ and found to be satisfactory.

Quality

- 22.1 The manufacture of the membrane has been examined by BRANZ, details regarding the quality and composition of the materials used were obtained by BRANZ and found to be satisfactory.
- 22.2 The quality management system of the membrane manufacturer has been assessed by BRANZ and found to be satisfactory.
- 22.3 The quality of supply of the membrane system materials to the market is the responsibility of Sika Australia Pty Ltd.
- 22.4 Quality on-site is the responsibility of the Sika Australia Pty Ltd approved and trained applicators.
- 22.5 Designers are responsible for the substrate design, and building contractors are responsible for the quality of construction of substrate systems in accordance with the instructions of the substrate manufacturer, Sika Australia Pty Ltd and this Appraisal.
- 22.6 Building owners are responsible for the maintenance of the tiling systems in accordance with the instructions of Sika Australia Pty Ltd.

Sources of Information

- AS 3958.1:2007 Ceramic Tiles - Guide to the installation of ceramic tiles.
- AS/NZS 2269:2012 Plywood - Structural.
- AS/NZS 2908.2:2000 Cellulose-cement products - Flat sheet.
- AS/NZS 4858:2004 Wet area membranes.
- BRANZ Good Practice Guide: Tiling [Third Edition], April 2015.
- National Construction Code 2022, Australian Building Codes Board.



In the opinion of BRANZ, **Sika Sikatite WPU Exterior** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **Sika Australia Pty Ltd**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **Sika Australia Pty Ltd:**
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and quality of work;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **Sika Australia Pty Ltd**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **Sika Australia Pty Ltd** or any third party.

For BRANZ



Claire Falck

Chief Executive

Date of Issue:

30 August 2024