

FC11070-01-2-C1

ASSESSMENT SUMMARY



This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Test Sponsor

Autex Industries limited
702-718 Rosebank Road
Avondale
Auckland, 1026
New Zealand

Reference BRANZ Fire Assessment

FC11070-01-2 – issued 18/06/2024

Test standard

AS ISO 9705:2003 (R2016) and ISO 9705:1993

Specimen name

The range of Autex polyester products- including Quietspace Panel, Quietspace Ceiling Tiles, Composition, Symphony, Vertiface, Cube, Workstation, GreenStuf Underfloor and 13 versions of GreenStuf, up to a weight of 4,800 gsm.

Specimen description

The above Autex polyester products adhered to paper-faced plasterboard substrate

Orientation


As tested, base adhered to substrate

A full description of the performance assessment is given in BRANZ Fire Assessment FC11070-01-2 issued 18/06/2024

Regulatory authorities are advised to examine reports before approving any product. The conclusion of the BRANZ Fire Assessment provides the following Building Code Classifications

Building Code Document	Group Number Classification
NCC Volume One Specification 7, Clause S7C4 determined in accordance with AS 5637.1	1 SMOGR _{RC} not more than 100 m ² /s ² x 1000
NZBC Verification Method C/VM2 Appendix A: Establishing Group Numbers for lining materials	1-S Smoke Production Rate not more than 5 m ² /s

Issued by


L. Q. Greive
Fire Testing Engineer
BRANZ

Reviewed and Authorised by


L. F. Hersche
Fire Testing Engineer
BRANZ

Issue Date

18/06/2024