



# Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

ARA Group NZ Ltd (T/A Metalbilt Doors)  
26 Timothy Place, Avondale  
Auckland 1026

**Test standard:** AS 1530.4-2005/2014

**Specimen name:** Metalbilt roller shutter installed in a fire rated masonry wall

**Specimen description:** Metalbilt roller shutter installed in fire rated masonry wall with an established 240 minute FRR. The maximum clear opening dimensions shall not exceed 6,000 mm high or 7,500 mm wide (maximum area limited to 40 m<sup>2</sup>).

**Orientation:** Fire exposure from either side.

**A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:**

BRANZ Fire Assessment Reports FC17323-03-1

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

**Regulatory authorities are advised to examine test reports before approving any product.**

**The assessed results were as follows:**

**Integrity – 240 minutes  
(FRR -/240/0)**

**Certificate issued:** 11 February 2025

**Certificate Number:** FC19512-01-C2-1

P Chapman  
Senior Fire Testing Engineer  
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."