

## **Fire Test Certificate**

## This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Unihatch NZ Ltd 24 Hawdon Street Sydenham Christchurch New Zealand

**Test standard:** AS 1530.4-2005/2014

**Specimen name:** Unihatch Goliath Fire hatch

**Specimen description:** 

Steel framed fire hatch up to 600 mm x 600 mm installed in a suspended plasterboard floor/ceiling system. The opening in the ceiling is to be framed with steel studs which are supported by brackets to the structure above. The opening is lined with plasterboard and the fire hatch frame secured through the plasterboard to the independently supported steel studs. The fire hatch panel is faced with MDF and nominally 40 mm thick.

The fire hatch must be independently supported from the ceiling framing and plasterboard.

The fire hatch may be any dimension less than 600 mm x 600 mm on the condition it has at least two hinges and one latch i.e. 600 mm x 300 mm.

**Orientation:** Exposure from the underside only.

A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:

BRANZ Fire Assessment Reports FC10139-02-2

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports before approving any product.

The fire hatch can be installed into the following GIB® fire rated floor/ceiling system:

FRR 60/60/60 - GBSC 60a

Certificate issued: 1 May 2025 Certificate Number: FC10139-02-2-C1

P Chapman Senior Fire Testing Engineer For BRANZ Limited





This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."