



Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Autex Industries Limited
702-718 Rosebank Road
Avondale
Auckland 1026
New Zealand

Test standard: AS 1530.4-2005/2014

Specimen name: Winstone Wallboards Ltd GIB® Noise Control systems with Autex GreenStuf® R2.0 wall or Autex GreenStuf® Sound Solution® insulation.

Specimen description: Winstone Wallboards Limited fire rated Noise Control wall systems with Autex GreenStuf® R2.0 wall or Autex GreenStuf® Sound Solution® insulation installed with the following GIB® systems:

GIB® system	FRR
GBSA 30b, GBSA 30r, GBSA 30s, GBQSA 30	-/30/30
GBTLA 30a, GBTLA 30b	30/30/30
GBSA 45, GBSA 45a, GBQSA 45	-/45/45
GBTLA 45r, GTBLIC 45	45/45/45
GBSAB 60a, GBSAB 60b, GBSAB 60c, GBSAB 60d, GBSAB 60e, GBSA 60c, GBSA 60r, GBQSA 60a, GBQSA 60	-/60/60
GBTLAB 60a, GBTLAB 60b, GBTLAB 60c, GBTLAB 60d, GBTLA 60, GBTLA 60r, GTBLIC 60, GTBLIC 60a,	60/60/60
GBSA 90c, GBSA 90d, GBSA 90r, GBSA 90s, GBQSA 90	-/90/90
GBTLA 90c, GBTLA 90d, GBTLA 90r	90/90/90

Orientation: Fire exposure from either side.

A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:

BRANZ Fire Assessment Report FAR 4713 Issue 2

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports before approving any product.

Certificate issued: 12 June 2025

Certificate Number: FAR 4713-2-C1

P Chapman
Senior Fire Engineer
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."