



**BRANZ Appraised**  
Appraisal No. 1167 [2021]

## PLATINUM PLUS ROOF UNDERLAY

**Appraisal No. 1167 [2021]**

Amended 02 February 2026



### BRANZ Appraisals

Technical Assessments of  
products for building and  
construction.



### E Built NZ Limited

PO Box 305 226  
Triton Plaza  
North Shore 0757  
Auckland

Tel: 09 916 6750

Email: [orders@ebuilt.co.nz](mailto:orders@ebuilt.co.nz)

Web: [ebuilt.co.nz](http://ebuilt.co.nz)



### BRANZ

#### BRANZ

1222 Moonshine Rd,  
RD1, Porirua 5381  
Private Bag 50 908  
Porirua 5240,  
New Zealand  
Tel: 04 237 1170  
[branz.co.nz](http://branz.co.nz)



## Product

- 1.1 Platinum Plus Roof Underlay is a synthetic building underlay for use under roof claddings. The underlay consists of a micro-porous, water-resistant film laminated to two layers of non-woven, spun-bonded polyolefin and is coloured white on both faces.

## Scope

- 2.1 Platinum Plus Roof Underlay has been appraised as a self supporting roof underlay on buildings within the following scope:
  - the scope limitations of NZBC Acceptable Solution E2/AS1 for timber-framed buildings; or,
  - the scope limitations of NASH Building Envelope Solutions for steel-framed buildings; and,
  - with masonry tile roof cladding; and,
  - with metal tile and profiled metal roof cladding; and,
  - situated in NZS 3604 Wind Zones up to, and including, Extra High.

## Building Regulations

### New Zealand Building Code (NZBC)

- 3.1 In the opinion of BRANZ, Platinum Plus Roof Underlay, if used, designed, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet, or contribute to meeting the following provisions of the NZBC:

**Clause B2 DURABILITY:** Performance B2.3.1 [a] not less than 50 years, B2.3.1 [b] 15 years and B2.3.2. Platinum Plus Roof Underlay meets these requirements. See Paragraphs 9.1 and 9.2.

**Clause C3 FIRE AFFECTING AREAS BEYOND THE FIRE SOURCE:** Performance C3.4 [c]. Platinum Plus Roof Underlay meets this requirement. See Paragraph 10.1.

**Clause E2 EXTERNAL MOISTURE:** Performance E2.3.2. When used as part of the roof cladding system, Platinum Plus Roof Underlay contributes to meeting this requirement. See Paragraphs 12.1 and 12.2.

**Clause F2 HAZARDOUS BUILDING MATERIALS:** Performance F2.3.1. Platinum Plus Roof Underlay meets this requirement.



## Technical Specification

- 4.1 Platinum Plus Roof Underlay is a spun-bonded polyolefin, non-woven fabric laminated with a breathable coating for use under roof claddings. Platinum Plus Roof Underlay is coloured white on both faces.
- 4.2 The product is supplied in rolls 1.5 m wide x 50 m long. The product is printed with the Platinum Plus Roof Underlay logo repeated along the length of the roll. The rolls are wrapped in clear polythene film.

### Accessories

- 4.3 Accessories used with Platinum Plus Roof Underlay, which are supplied by the installer are:
  - **Fixings** - stainless steel staples, clouts, screws or proprietary underlay fixings, or other temporary fixings to attach the roof underlay to the framing.

## Handling and Storage

- 5.1 Handling and storage of the product, whether on-site or off-site, is under the control of the installer. The rolls must be protected from damage and weather. They must be stored on end, under cover, in clean dry conditions and must not be crushed.

## Technical Literature

- 6.1 This Appraisal must be read in conjunction with:
  - Ventia Iron Platinum Plus Installation Procedure, Version 1, August 2021.
- 6.2 All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

## Design Information

### General

- 7.1 Platinum Plus Roof Underlay is suitable for use at roof pitches 3° and above. The product must not span unsupported more than 1,200 mm in one direction. Spans greater than 1,200 mm require additional support such as galvanised wire or safety mesh.
- 7.2 When used at pitches less than 10°, Platinum Plus Roof Underlay can be installed horizontally, or it can be installed vertically when fully supported by a corrosion resistant material.
- 7.3 At pitches 10° and greater, Platinum Plus Roof Underlay can be installed vertically, or horizontally.
- 7.4 Platinum Plus Roof Underlay is intended for use as an alternative to conventional kraft paper roof underlays, which are fixed over timber or steel-framed roofs in order to limit the entry of wind into the roof cavity, and to assist in the moisture management of the roof cladding system.
- 7.5 The material also provides a degree of temporary weather protection during early construction. However, the product will not make the roof weathertight and some wetting of the underlying structure is always possible before the roof cladding is installed. Hence, the entire building must be closed-in and made weatherproof before moisture sensitive materials such as ceiling linings and insulation materials are installed.
- 7.6 Platinum Plus Roof Underlay must not be exposed to the weather or ultraviolet [UV] light for a total of more than 7 days before being covered by the roof cladding.
- 7.7 Platinum Plus Roof Underlay is suitable for use under roof cladding on buildings as a roof underlay in accordance with NZBC Acceptable Solution E2/AS1 or NASH Building Envelope Solutions. Refer to Table 1 for the material properties of Platinum Plus Roof Underlay.



**Table 1: NZBC Acceptable Solution E2/AS1 Requirements**

NZBC E2/AS1 Roof Underlay Properties	Property Performance Requirement	Results
Absorbency	$\geq 150 \text{ g/m}^2$	Pass
Vapour Resistance	$\leq 7 \text{ MN s/g}$	Pass
Water Resistance	$\geq 100 \text{ mm}$	Pass
pH of Extract	$\geq 5.5$ and $\leq 8$	Pass
Shrinkage	$\leq 0.5\%$	Pass
Mechanical	Edge tear and tensile strength	<b>Edge tear [Average]:</b> Machine direction = 235 N Cross direction = 158 N  <b>Tensile strength [Average]:</b> Machine direction = 7.99 kN/m Cross direction = 5.68 kN/m

**Table 2: Roof Underlay Support Requirements**

Roof Pitch	Span	Roof Underlay Support Required?	
		Horizontally Installed	Vertically Installed
10° or more	Greater than 1,200 mm	Yes	Yes
	1,200 mm or less	No	No
Less than 10° (Minimum 3°)	Greater than 1,200 mm	Yes	Yes
	1,200 mm or less	No	Yes

### Structure

8.1 Platinum Plus Roof Underlay is suitable for use in all Wind Zones of NZS 3604 up to, and including, Extra High.

### Durability

9.1 Platinum Plus Roof Underlay meets code compliance with NZBC Clause B2.3.1 [a] not less than 50 years for roof underlays used where the roof cladding durability requirement or expected serviceable life is not less than 50 years, e.g. behind masonry roof tile cladding, and code compliance with NZBC Clause B2.3.1 [b] 15 years for roof underlays used where the roof cladding durability requirement is 15 years.

### Serviceable Life

9.2 Provided it is not exposed to the weather or UV light for a total of more than 7 days, and provided the roof cladding is maintained in accordance with the cladding manufacturer's instructions and the roof cladding remains weather-resistant, Platinum Plus Roof Underlay is expected to have a serviceable life equal to that of the roof cladding.

### Control of Internal Fire and Smoke Spread

10.1 Platinum Plus Roof Underlay has an AS 1530 Part 2 flammability index of not greater than 5, and therefore meets the requirements of NZBC Acceptable C/AS2, for the surface finish requirements of suspended flexible fabric used as an underlay to exterior cladding that is exposed to view in occupied spaces. It may therefore be used with no restrictions in all buildings.

### Prevention of Fire Occurring

11.1 Separation or protection must be provided to Platinum Plus Roof Underlay from heat sources such as fireplaces, heating appliances and chimneys. NZBC Acceptable Solutions C/AS1 and C/AS2 provide methods for separation and protection of combustible materials from heat sources.



## External Moisture

- 12.1 Platinum Plus Roof Underlay must only be used under roof claddings that meet the requirements of the NZBC, such as those covered by NZBC Acceptable Solution E2/AS1, or roof claddings covered by a valid BRANZ Appraisal.
- 12.2 Platinum Plus Roof Underlay, when installed in accordance with the Technical Literature and this Appraisal, will assist in the total cladding system's compliance with NZBC.

## Installation Information

### Installation Skill Level Requirement

- 13.1 All design and building work must be carried out in accordance with the Platinum Plus Roof Underlay Technical Literature and this Appraisal by competent and experienced tradespeople conversant with Platinum Plus Roof Underlay. Where the work involves Restricted Building Work (RBW) this must be completed by, or under the supervision of, a Licensed Building Practitioner (LBP) with the relevant Licence Class.

### Underlay Installation

- 14.1 Platinum Plus Roof Underlay must be fixed at maximum 300 mm centres to all framing members with large-head clouts 20 mm long, 6-8 mm stainless steel staples, self-drilling screws or proprietary underlay fixings. The underlay must be pulled taut over the framing before fixing.
- 14.2 Platinum Plus Roof Underlay may be installed horizontally or vertically at roof pitches 3° and above (refer to Paragraph 7.2 for further guidance). It must extend from the ridge and overhang the fascia board by 20-25 mm. Vertical laps must be no less than 150 mm wide. Horizontal laps must also be no less than 150 mm, with the direction of the lap ensuring that water is shed to the outer face of the underlay. End laps must be made over framing and be no less than 150 mm wide.
- 14.3 When fixing the product in windy conditions, care must be taken due to the large sail area created.
- 14.4 Any damaged areas of Platinum Plus Roof Underlay, such as tears, holes or gaps around service penetrations, must be repaired. Damaged areas can be repaired by covering with new material lapping the damage area by at least 50 mm and taping, or by taping small tears.

### Inspections

- 14.5 The Technical Literature must be referred to during the inspection of Platinum Plus Roof Underlay installations.

## Basis of Appraisal

The following is a summary of the technical investigations carried out:

### Tests

- 15.1 The following tests have been carried out on Platinum Plus Roof Underlay in accordance with NZBC Acceptable Solution E2/AS1, tensile strength, edge-tear resistance and resistance to water vapour transmission in accordance with AS/NZS 4200.1, shrinkage in accordance with AS/NZS 4201.3, resistance to water penetration in accordance with AS/NZS 4201.4, surface water absorbency in accordance with AS/NZS 4201.6, pH of extract in accordance with AS/NZS 1301.421s. A range of these tests were completed before and after the underlay was exposed to UV light.
- 15.2 The flammability index of Platinum Plus Roof Underlay has been evaluated in accordance with AS 1530.2.

### Other Investigations

- 16.1 A durability opinion has been given by BRANZ technical experts.
- 16.2 An evaluation of the expected performance of Platinum Plus Roof Underlay in direct contact with metal roof cladding has been completed by BRANZ.
- 16.3 The practicability of installation of Platinum Plus Roof Underlay has been assessed by BRANZ and found to be satisfactory.



16.4 The Technical Literature, including installation instructions, has been examined by BRANZ and found to be satisfactory.

### Quality

- 17.1 The manufacture of Platinum Plus Roof Underlay has not been examined by BRANZ, but details of the methods adopted for quality control and the quality of the materials used, have been obtained and found to be satisfactory. BRANZ undertakes an ongoing review of product quality on an inwards goods basis.
- 17.2 The quality of supply to the market is the responsibility of E Built NZ Limited.
- 17.3 Building designers are responsible for the design of the building, and for the incorporation of the roof underlay into their design in accordance with the instructions of E Built NZ Limited.
- 17.4 Quality of installation is the responsibility of the installer in accordance with the instructions of E Built NZ Limited.

### Sources of Information

- AS 1530.2:1993 Test for flammability of materials.
- AS/NZS 1301.421s:1998 Determination of the pH value of aqueous extracts of paper, board and pulp - Cold extraction method.
- AS/NZS 4200.1:1994 Pliable building membranes and underlays - Materials.
- AS/NZS 4201.3:1994 Pliable building membranes and underlays - Methods of test - Shrinkage.
- AS/NZS 4201.4:1994 Pliable building membranes and underlays - Methods of test - Resistance to water penetration.
- AS/NZS 4201.6:1994 Pliable building membranes and underlays - Methods of test - Surface water absorbency.
- AS/NZS 4534:2006 Zinc and zinc/aluminium-alloy coatings on steel wire.
- NASH Building Envelope Solutions: 2019 Light steel-framed buildings.
- NASH Standard Part Two: 2019 Light steel-framed buildings.
- NZS 3604:2011 Timber-framed buildings.
- Ministry of Business, Innovation and Employment Record of amendments - Acceptable Solutions, Verification Methods and handbooks.
- The Building Regulations 1992.

### Amendments

#### Amendment No. 1, dated 12 October 2023

This Appraisal has been amended to change the underlay colour to white on both faces.

#### Amendment No. 2, dated 02 February 2026

This Appraisal has been amended to reflect the changes made to the NZBC compliance documentation and to update the Appraisal Holder's contact details.



**BRANZ Appraised**  
Appraisal No. 1167 [2021]

**BRANZ Appraisal**  
Appraisal No. 1167 [2021]  
18 November 2021

PLATINUM PLUS  
ROOF UNDERLAY



In the opinion of BRANZ, **Platinum Plus Roof Underlay** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **E Built NZ Limited**, and is valid until further notice, subject to the Conditions of Appraisal.

### Conditions of Appraisal

1. This Appraisal:
  - a) relates only to the product as described herein;
  - b) must be read, considered and used in full together with the Technical Literature;
  - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
  - d) is copyright of BRANZ.
2. **E Built NZ Limited**:
  - a) continues to have the product reviewed by BRANZ;
  - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
  - c) abides by the BRANZ Appraisals Services Terms and Conditions;
  - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
  - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and quality of work;
  - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
  - c) any guarantee or warranty offered by **E Built NZ Limited**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **E Built NZ Limited** or any third party.

---

For BRANZ

**Chelydra Percy**

Chief Executive

Date of Issue:

18 November 2021