



Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Elephant Plasterboard (NZ) Ltd
14 Bancroft Crescent
Glendene
Auckland 0602
New Zealand

Test standard: AS 1530.4:2014

Specimen name: Elephant plasterboard steel and timber framed walls

Specimen description: Elephant plasterboard loadbearing timber and non-loadbearing steel framed walls lined with at least one layer of 13 mm thick, Elephant FireSmart plasterboard.

Orientation: Fire exposure from either side

A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:

BRANZ Fire Assessment Reports FC18359-01-1 and FC21452-01-1
BRANZ Fire Test Report FR21158-01-1

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports before approving any product.

The assessed results were as follows:

- FRL 60/60/60 - Loadbearing timber framed wall, single layer 13 mm FireSmart plasterboard per face with minimum plasterboard weight of 11.7 kg/m². **EPB System No. E2TL60**
- FRL -/60/60 - Non-loadbearing RONDO 64 steel framed wall, single layer 13 mm FireSmart plasterboard per face with minimum plasterboard weight of 11.7 kg/m² and including at least 75 mm thick R1.8 fibreglass insulation in the wall cavity. **EPB System No. E2S60**

Certificate issued: 26 February 2026

Certificate Number: FC21452-01-1-C1

S Whatham
Fire Testing Engineer
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

Page 1 of 1
The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."