



Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

Elephant Plasterboard (NZ) Ltd
14 Bancroft Crescent
Glendene
Auckland 0602

Test standard: AS 1530.4:2014

Specimen name: Elephant Plasterboard systems with CLAD solutions Ltd external cladding

Specimen description: Elephant Plasterboard fire rated timber framed, plasterboard wall systems with CLAD Solutions 15 mm thick Shera Weatherboard Bevelback cladding (ECW1TL30) or 10 mm thick Shera Shiplap Vertical MS200 cladding (ECSv1TL30).

The wall framing consists of minimum 90 mm x 45 mm timber studs at maximum 600 mm centres, noggs at maximum 600 mm centres. The CLAD Solutions cladding is installed over nominal 20 mm x 45 mm timber cavity battens.

EPB System	Internal/External Wall lining	FRR
ECW1TL30-F10	Internal - 1 x 10 mm EPB FireSmart® External – 15 mm Shera Weatherboard	30/30/30
ECW1TL30-F13	Internal - 1 x 13 mm EPB FireSmart® External – 15 mm Shera Weatherboard	30/30/30
ECSv1TL30-F10	Internal - 1 x 10 mm EPB FireSmart® External – 10 mm Shera Shiplap MS200	30/30/30
ECSv1TL30-F13	Internal - 1 x 13 mm EPB FireSmart® External – 10 mm Shera Shiplap MS200	30/30/30

Orientation: Fire exposure from either side.

A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:

BRANZ Fire Assessment Report FC21570-01-1

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

Regulatory authorities are advised to examine test reports before approving any product.

Certificate issued: 7 May 2026

Certificate Number: FC21570-01-C1-1

P Chapman
Senior Fire Testing Engineer
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."