

FC18171-01-2-C1 ASSESSMENT SUMMARY REPORT



This is to certify that the specimen described below have been examined by BRANZ on behalf of the sponsor.

Sponsor

Abodo Wood Limited
62 Ascot Road
Mangere
Auckland, 2022
New Zealand

Reference BRANZ Report

FC18171-01-2 – 8 May 2026

Product Names

Abodo® Vaaro™ treated timber
Abodo® Vaaro® Protector™ WB treated timber
Abodo® Vaaro® Protector™ 2 treated timber

Product as described by the sponsor

The products comprise nominally 18 mm thick solid Abodo® Vaaro® fire-retardant-treated timber boards, manufactured in either Flat Sawn (FS) or Laminated Vertical Grain (LAMVG) form.

Where applicable, the boards are coated with either Abodo Protector™ WB or Abodo Protector™ 2 stain systems, applied in accordance with the manufacturer's specifications.

The assessed stain colours are: White, Clear, Pearl, Patina, Straw, Teak, Walnut, Manuka, Ebony, Graphite, Nero, and Natural.

Regulatory authorities are advised to examine reference reports before approving any product.

Classification Document	Performance
NZBC Building Product Specifications (2025), Section 8.4, Table 8.4.1.2	Type A
NZBC Acceptable Solutions C/AS1 in accordance with Table 5.1: Requirements for external wall claddings	
NZBC Acceptable Solutions C/AS2, in accordance with Table C1.3: Classification of cladding materials	
Australian Standard: AS 3959:2018, Appendix F	Bushfire-resisting timber (BAL-29)

Issued by

L. Q. Greive
Fire Testing Engineer
BRANZ

Reviewed and authorised for release by

L. F. Hersche
Fire Testing Engineer
BRANZ

Issue Date

8 May 2026

